

# 屋内照明器具特性

|         |   |  |  |  |  |  |  |  |  |  |
|---------|---|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | SLB15785+SLK22011+SLK290                      |  |  |  |  |  |  |  |  |  |
| 光源      | LLD3411LCB1 ×1                      700.0 1 m |  |  |  |  |  |  |  |  |  |
| 管理番号    | K0193058 ( 0 ) DB 1                           |  |  |  |  |  |  |  |  |  |
| BZ分類    | BZ5 / 2.8 / BZ6                               |  |  |  |  |  |  |  |  |  |

|        |                  |          |                  |     |    |      |      |    |    |      |      |    |    |      |      |    |    |      |     |     |     |
|--------|------------------|----------|------------------|-----|----|------|------|----|----|------|------|----|----|------|------|----|----|------|-----|-----|-----|
| 器具効率   | 88 %             | 天井       | 80 %             |     |    |      | 70 % |    |    |      | 50 % |    |    |      | 30 % |    |    |      | 0 % |     |     |
|        | 上方光束             |          | 26 %             | 反射率 | 70 | 50   | 30   | 10 | 70 | 50   | 30   | 10 | 70 | 50   | 30   | 10 | 70 | 50   | 30  | 10  | 0 % |
|        | 下方光束             |          | 62 %             |     | 床  | 10 % |      |    |    | 10 % |      |    |    | 10 % |      |    |    | 10 % |     |     |     |
| 室指数    | 照明率 ( X0.01 )    |          |                  |     |    |      |      |    |    |      |      |    |    |      |      |    |    |      |     | ZCM |     |
| 保守率    | 良                | 0.63     | 0.6              | 47  | 37 | 31   | 26   | 45 | 36 | 30   | 26   | 40 | 33 | 28   | 24   | 36 | 30 | 26   | 23  | 19  |     |
|        | 中                | 0.6      | 0.8              | 54  | 45 | 38   | 33   | 51 | 43 | 37   | 32   | 46 | 39 | 34   | 30   | 41 | 36 | 31   | 28  | 24  |     |
|        | 否                | 0.56     | 1.0              | 59  | 50 | 43   | 38   | 56 | 48 | 42   | 37   | 50 | 44 | 38   | 35   | 45 | 40 | 35   | 32  | 27  |     |
|        |                  |          | 1.25             | 64  | 55 | 49   | 44   | 60 | 53 | 47   | 42   | 54 | 48 | 43   | 39   | 48 | 43 | 39   | 36  | 31  |     |
| 下方投影面積 | c m <sup>2</sup> |          | 1.5              | 67  | 59 | 53   | 48   | 64 | 56 | 51   | 46   | 57 | 51 | 47   | 43   | 51 | 46 | 43   | 39  | 34  |     |
|        | 等価発光面積           |          | c m <sup>2</sup> | 2.0 | 71 | 65   | 59   | 54 | 68 | 62   | 57   | 52 | 61 | 56   | 52   | 48 | 55 | 51   | 47  | 44  | 38  |
| 取付高さ   | 器具間隔最大限          |          | 2.5              | 74  | 68 | 63   | 59   | 71 | 65 | 61   | 57   | 64 | 59 | 56   | 52   | 57 | 54 | 51   | 48  | 41  |     |
|        | 横方向 (A)          | 縦方向 (B)  | 3.0              | 76  | 71 | 66   | 62   | 73 | 68 | 64   | 60   | 65 | 62 | 58   | 55   | 59 | 56 | 53   | 51  | 43  |     |
| H m    | 0.60 H m         | 0.60 H m | 4.0              | 79  | 75 | 71   | 67   | 75 | 71 | 68   | 65   | 68 | 65 | 62   | 59   | 61 | 59 | 56   | 54  | 46  |     |
|        |                  |          | 5.0              | 81  | 77 | 74   | 71   | 77 | 74 | 71   | 68   | 70 | 67 | 64   | 62   | 63 | 61 | 59   | 57  | 48  |     |
|        |                  |          | 7.0              | 83  | 80 | 77   | 75   | 79 | 76 | 74   | 72   | 72 | 70 | 68   | 66   | 65 | 63 | 61   | 60  | 51  |     |
|        |                  |          | 10.0             | 85  | 82 | 80   | 78   | 81 | 79 | 77   | 75   | 73 | 72 | 70   | 69   | 66 | 65 | 64   | 63  | 54  |     |

