

屋内照明器具特性

| | | |
|---------|---|--|
| 品番 (品名) | SLB15785 + SLK22013 + SLK290 | |
| 光源 | LLD3411LCB1 ×1 700.0 1 m | |
| 管理番号 | K0193058 (0) DB 1 | |
| BZ分類 | BZ5 / 2.8 / BZ6 | |

| | | | | | | | | | | | | | | | | | | | | | |
|--------|------------------|------------------|------|------|----|------|------|----|----|------|------|----|----|------|------|----|----|------|-----|----|-----|
| 器具効率 | 88 % | 天井 | 80 % | | | | 70 % | | | | 50 % | | | | 30 % | | | | 0 % | | |
| | 上方光束 | | 26 % | 壁 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 0 % |
| | 下方光束 | | 62 % | | 床 | 10 % | | | | 10 % | | | | 10 % | | | | 10 % | | | |
| 室指数 | 照明率 (X0.01) | | | | | | | | | | | | | | | | | | | | ZCM |
| 保守率 | 良 | 0.63 | 0.6 | 47 | 37 | 31 | 26 | 45 | 36 | 30 | 26 | 40 | 33 | 28 | 24 | 36 | 30 | 26 | 23 | 19 | |
| | 中 | 0.6 | 0.8 | 54 | 45 | 38 | 33 | 51 | 43 | 37 | 32 | 46 | 39 | 34 | 30 | 41 | 36 | 31 | 28 | 24 | |
| | 否 | 0.56 | 1.0 | 59 | 50 | 43 | 38 | 56 | 48 | 42 | 37 | 50 | 44 | 38 | 35 | 45 | 40 | 35 | 32 | 27 | |
| | 下方投影面積 | c m ² | | 1.25 | 64 | 55 | 49 | 44 | 60 | 53 | 47 | 42 | 54 | 48 | 43 | 39 | 48 | 43 | 39 | 36 | 31 |
| 等価発光面積 | c m ² | | 1.5 | 67 | 59 | 53 | 48 | 64 | 56 | 51 | 46 | 57 | 51 | 47 | 43 | 51 | 46 | 43 | 39 | 34 | |
| | c m ² | | 2.0 | 71 | 65 | 59 | 54 | 68 | 62 | 57 | 52 | 61 | 56 | 52 | 48 | 55 | 51 | 47 | 44 | 38 | |
| 取付高さ | 器具間隔最大限 | | 2.5 | 74 | 68 | 63 | 59 | 71 | 65 | 61 | 57 | 64 | 59 | 56 | 52 | 57 | 54 | 51 | 48 | 41 | |
| | 横方向 (A) | 縦方向 (B) | 3.0 | 76 | 71 | 66 | 62 | 73 | 68 | 64 | 60 | 65 | 62 | 58 | 55 | 59 | 56 | 53 | 51 | 43 | |
| H m | 0.60 H m | 0.60 H m | 4.0 | 79 | 75 | 71 | 67 | 75 | 71 | 68 | 65 | 68 | 65 | 62 | 59 | 61 | 59 | 56 | 54 | 46 | |
| | | | 5.0 | 81 | 77 | 74 | 71 | 77 | 74 | 71 | 68 | 70 | 67 | 64 | 62 | 63 | 61 | 59 | 57 | 48 | |
| | | | 7.0 | 83 | 80 | 77 | 75 | 79 | 76 | 74 | 72 | 72 | 70 | 68 | 66 | 65 | 63 | 61 | 60 | 51 | |
| | | | 10.0 | 85 | 82 | 80 | 78 | 81 | 79 | 77 | 75 | 73 | 72 | 70 | 69 | 66 | 65 | 64 | 63 | 54 | |

