

| 屋内照明器具特性 |                                                              |
|----------|--------------------------------------------------------------|
| 品番 (品名)  | X F L 3 2 3 E Z                                              |
| 光源       | LDL40S. N / 14 / 26 ( 2 6 0 0 A ) × 2      2 6 0 0 . 0   l m |
| 管理番号     | K 0 1 2 6 6 8 7 ( 1 ) D B 1                                  |
| B Z 分類   | B Z 3 / 0 . 7 / B Z 2                                        |

| 器具効率     |           | 6 4 %            | 反射率       | 天井                | 8 0 % |     |     |     | 7 0 % |     |     |     | 5 0 % |     |     |     | 3 0 % |     |     |     | 0 % |       |
|----------|-----------|------------------|-----------|-------------------|-------|-----|-----|-----|-------|-----|-----|-----|-------|-----|-----|-----|-------|-----|-----|-----|-----|-------|
|          |           |                  |           | 壁                 | 7 0   | 5 0 | 3 0 | 1 0 | 7 0   | 5 0 | 3 0 | 1 0 | 7 0   | 5 0 | 3 0 | 1 0 | 7 0   | 5 0 | 3 0 | 1 0 | 0 % |       |
|          |           |                  |           | 床                 | 1 0 % |     |     |     | 1 0 % |     |     |     | 1 0 % |     |     |     | 1 0 % |     |     |     | 0 % |       |
| 上方光束     |           | 0 %              | 室指数       | 照明率 ( X 0 . 0 1 ) |       |     |     |     |       |     |     |     |       |     |     |     |       |     |     |     |     | Z C M |
| 下方光束     |           | 6 4 %            |           |                   |       |     |     |     |       |     |     |     |       |     |     |     |       |     |     |     |     |       |
| 保守率      |           | 良<br>中<br>否      | 0 . 8 1   | 0 . 6             | 4 1   | 3 5 | 3 0 | 2 7 | 4 0   | 3 4 | 3 0 | 2 7 | 3 9   | 3 4 | 3 0 | 2 7 | 3 8   | 3 3 | 3 0 | 2 7 | 2 6 |       |
|          |           |                  | 0 . 7 7   | 0 . 8             | 4 8   | 4 2 | 3 8 | 3 5 | 4 7   | 4 2 | 3 8 | 3 5 | 4 6   | 4 1 | 3 8 | 3 5 | 4 5   | 4 0 | 3 7 | 3 5 | 3 4 |       |
|          |           |                  | 0 . 6 8   | 1 . 0             | 5 2   | 4 7 | 4 4 | 4 1 | 5 2   | 4 7 | 4 3 | 4 1 | 5 0   | 4 6 | 4 3 | 4 0 | 4 9   | 4 5 | 4 2 | 4 0 | 3 9 |       |
|          |           |                  |           | 1 . 2 5           | 5 6   | 5 1 | 4 8 | 4 5 | 5 5   | 5 1 | 4 8 | 4 5 | 5 3   | 5 0 | 4 7 | 4 5 | 5 2   | 4 9 | 4 6 | 4 4 | 4 3 |       |
| 下方投影面積   |           | c m <sup>2</sup> | 1 . 5     | 5 8               | 5 4   | 5 1 | 4 8 | 5 7 | 5 3   | 5 0 | 4 8 | 5 5 | 5 2   | 5 0 | 4 8 | 5 4 | 5 1   | 4 9 | 4 7 | 4 6 |     |       |
| 等価発光面積   |           | c m <sup>2</sup> | 2 . 0     | 6 1               | 5 7   | 5 5 | 5 3 | 6 0 | 5 7   | 5 4 | 5 2 | 5 8 | 5 6   | 5 4 | 5 2 | 5 7 | 5 5   | 5 3 | 5 1 | 5 0 |     |       |
| 取付<br>高さ | 器具間隔最大限   |                  | 2 . 5     | 6 2               | 6 0   | 5 7 | 5 5 | 6 2 | 5 9   | 5 7 | 5 5 | 6 0 | 5 8   | 5 6 | 5 4 | 5 9 | 5 7   | 5 5 | 5 4 | 5 2 |     |       |
|          | 横方向 ( A ) |                  | 縦方向 ( B ) | 3 . 0             | 6 3   | 6 1 | 5 9 | 5 7 | 6 3   | 6 1 | 5 9 | 5 7 | 6 1   | 5 9 | 5 8 | 5 6 | 6 0   | 5 8 | 5 7 | 5 6 | 5 4 |       |
| 1 . 5m   | 2 . 2 2 m | 1 . 9 9 m        | 4 . 0     | 6 5               | 6 3   | 6 1 | 6 0 | 6 4 | 6 2   | 6 1 | 6 0 | 6 3 | 6 1   | 6 0 | 5 9 | 6 1 | 6 0   | 5 9 | 5 8 | 5 6 |     |       |
| 2        | 2 . 9 4   | 2 . 5            | 5 . 0     | 6 6               | 6 4   | 6 3 | 6 2 | 6 5 | 6 4   | 6 2 | 6 1 | 6 3 | 6 2   | 6 1 | 6 0 | 6 2 | 6 1   | 6 0 | 5 9 | 5 8 |     |       |
| 2 . 5    | 3 . 6 6   | 3 . 0 2          | 7 . 0     | 6 7               | 6 5   | 6 4 | 6 4 | 6 6 | 6 5   | 6 4 | 6 3 | 6 4 | 6 3   | 6 3 | 6 2 | 6 3 | 6 2   | 6 2 | 6 1 | 5 9 |     |       |
| 3        | 4 . 3 8   | 3 . 5 5          | 1 0 . 0   | 6 7               | 6 6   | 6 6 | 6 5 | 6 7 | 6 6   | 6 5 | 6 4 | 6 5 | 6 4   | 6 4 | 6 3 | 6 4 | 6 3   | 6 3 | 6 2 | 6 0 |     |       |

