

屋内照明器具特性	
品番 (品名)	X F L 3 2 6 E X
光源	LDL40S. N/ 14/ 26 (2 6 0 0 A) ×2 2 6 0 0 . 0 1 m
管理番号	K 0 1 2 6 5 0 1 (3) D B 1
B Z 分類	B Z 3 / 0 . 9 / B Z 2

器具効率		7 3 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %			
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %			
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %			
上方光束		0 %	室指数	照明率 (X 0 . 0 1) Z C M																		下方光束		7 3 %
保守率		良 0 . 8 1 中 0 . 7 7 否 1 . 0 0 . 6 8		0 . 6 0 . 8 1 . 0 1 . 2 5	4 5 5 4 6 0 6 4	3 7 4 7 5 4 5 9	3 2 4 3 4 9 5 5	2 9 3 9 4 6 5 2	4 4 5 3 5 9 6 3	3 7 4 7 5 3 5 8	3 2 4 2 4 9 5 4	2 8 3 9 4 6 5 2	4 3 5 2 5 7 6 1	3 6 4 6 5 2 5 7	3 2 4 2 4 8 5 4	2 8 3 9 4 6 5 1	4 1 5 0 5 5 5 9	3 5 4 5 5 1 5 6	3 1 4 1 4 8 5 3	2 8 3 9 4 5 5 1	2 7 3 7 4 4 4 9			
下方投影面積		c m ²	1 . 5	6 6	6 2	5 8	5 5	6 5	6 1	5 8	5 5	6 4	6 0	5 7	5 5	6 2	5 9	5 6	5 3	5 1	4 9			
等価発光面積		c m ²	2 . 0	7 0	6 6	6 3	6 1	6 9	6 5	6 3	6 0	6 7	6 4	6 2	6 0	6 5	6 3	6 1	5 9	5 8				
取付高さ	器具間隔最大限		2 . 5	7 2	6 9	6 6	6 4	7 1	6 8	6 6	6 4	6 9	6 7	6 5	6 3	6 7	6 5	6 4	6 2	6 0				
	横方向 (A)	縦方向 (B)	3 . 0	7 3	7 0	6 8	6 6	7 2	7 0	6 8	6 6	7 0	6 8	6 6	6 5	6 9	6 7	6 5	6 4	6 2				
1 . 5m	2 . 7 3 m	2 . 0 9 m	4 . 0	7 5	7 3	7 1	6 9	7 4	7 2	7 0	6 9	7 2	7 0	6 9	6 8	7 0	6 9	6 8	6 7	6 5				
2	3 . 6 4	2 . 6 4	5 . 0	7 5	7 4	7 2	7 1	7 5	7 3	7 2	7 0	7 3	7 2	7 0	6 9	7 1	7 0	6 9	6 8	6 6				
2 . 5	4 . 5 6	3 . 2 1	7 . 0	7 7	7 5	7 4	7 3	7 6	7 5	7 3	7 3	7 4	7 3	7 2	7 1	7 2	7 2	7 1	7 0	6 8				
3	5 . 4 7	3 . 7 8	1 0 . 0	7 7	7 6	7 6	7 5	7 6	7 6	7 5	7 4	7 5	7 4	7 3	7 3	7 3	7 3	7 3	7 2	7 0				

