

屋内照明器具特性	
品番 (品名)	X F L 3 2 6 P F
光源	LDL40S. N/ 14/ 26 (2 6 0 0 A) × 2 2 6 0 0 . 0 l m
管理番号	K 0 1 2 6 2 2 4 (1) D B 1
B Z 分類	B Z 5

器具効率		6 6 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
上方光束		0 %		床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
下方光束		6 6 %	室指数	照明率 (X 0 . 0 1) Z C M																	
保守率		良 中 否	0 . 7 7	0 . 6	3 7	2 9	2 4	2 1	3 6	2 9	2 4	2 0	3 5	2 8	2 4	2 0	3 3	2 7	2 3	2 0	1 9
			0 . 7 2	0 . 8	4 4	3 6	3 1	2 7	4 3	3 6	3 1	2 7	4 1	3 5	3 1	2 7	3 9	3 4	3 0	2 7	2 6
			1 . 0	4 8	4 1	3 6	3 2	4 7	4 1	3 6	3 2	4 5	4 0	3 5	3 2	4 4	3 9	3 5	3 2	3 0	
			0 . 6 8	1 . 2 5	5 2	4 6	4 1	3 7	5 1	4 5	4 1	3 7	4 9	4 4	4 0	3 7	4 7	4 3	3 9	3 7	3 5
下方投影面積		c m ²	1 . 5	5 5	4 9	4 5	4 1	5 4	4 9	4 4	4 1	5 2	4 7	4 4	4 1	5 0	4 6	4 3	4 0	3 9	
等価発光面積		c m ²	2 . 0	5 9	5 4	5 0	4 7	5 8	5 3	4 9	4 6	5 6	5 2	4 9	4 6	5 4	5 0	4 8	4 5	4 4	
取付 高さ	器具間隔最大限		2 . 5	6 1	5 7	5 3	5 0	6 0	5 6	5 3	5 0	5 8	5 5	5 2	4 9	5 6	5 3	5 1	4 9	4 7	
	横方向 (A) 縦方向 (B)		3 . 0	6 3	5 9	5 6	5 3	6 2	5 8	5 5	5 3	6 0	5 7	5 4	5 2	5 8	5 5	5 3	5 1	5 0	
1 . 5m	1 . 9 4 m	2 . 1 8 m	4 . 0	6 5	6 2	5 9	5 7	6 4	6 1	5 9	5 7	6 2	6 0	5 8	5 6	6 0	5 8	5 6	5 5	5 3	
2	2 . 5 7	2 . 7 5	5 . 0	6 6	6 3	6 1	5 9	6 5	6 3	6 1	5 9	6 3	6 1	6 0	5 8	6 1	6 0	5 8	5 7	5 5	
2 . 5	3 . 1 9	3 . 3 4	7 . 0	6 7	6 6	6 4	6 2	6 6	6 5	6 3	6 2	6 5	6 3	6 2	6 1	6 3	6 2	6 1	6 0	5 8	
3	3 . 8 1	3 . 9 4	1 0 . 0	6 8	6 7	6 6	6 5	6 7	6 6	6 5	6 4	6 6	6 5	6 4	6 3	6 4	6 3	6 3	6 2	6 0	

