

屋内照明器具特性

品番 (品名)	X L F 4 4 6 U T N J (J Y O U J I)									
光源	L E D 5 0 0 0 _ 8 5 _ 2 5 0 0 × 1 2 5 0 0 . 0 l m									
管理番号	K 0 1 5 3 3 5 4 (4) D B 1									
B Z 分類	B Z 1 0									

器具効率		1 0 0 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %		
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %		
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %		
上方光束		4 9 %	室指数	照明率 (X 0 . 0 1)																			Z C M
下方光束		5 1 %																					
保守率		良	0 . 8 3	0 . 6	4 2	2 9	2 1	1 5	3 8	2 7	1 9	1 4	3 1	2 2	1 6	1 1	2 4	1 7	1 2	8	3		
		中	0 . 8 1	0 . 8	5 0	3 7	2 8	2 2	4 6	3 4	2 6	2 0	3 7	2 8	2 1	1 6	2 9	2 2	1 7	1 3	6		
		否	0 . 7 7	1 . 0	5 6	4 4	3 4	2 8	5 1	4 0	3 2	2 5	4 1	3 3	2 6	2 1	3 3	2 6	2 0	1 6	8		
		1 . 2 5	6 2	5 0	4 1	3 4	5 6	4 5	3 7	3 1	4 6	3 7	3 1	2 6	3 6	3 0	2 4	2 0	1 1				
下方投影面積		c m ²	1 . 5	6 6	5 5	4 6	3 9	6 0	5 0	4 2	3 6	4 9	4 1	3 5	3 0	3 9	3 3	2 8	2 4	1 4			
			等価発光面積	c m ²	2 . 0	7 2	6 2	5 4	4 7	6 6	5 7	4 9	4 3	5 4	4 7	4 1	3 6	4 3	3 8	3 3	2 9	1 8	
取付高さ	器具間隔最大限		2 . 5	7 6	6 7	5 9	5 3	6 9	6 1	5 5	4 9	5 7	5 1	4 6	4 1	4 6	4 1	3 7	3 3	2 1			
	横方向 (A)	縦方向 (B)	3 . 0	7 8	7 0	6 4	5 7	7 2	6 5	5 9	5 3	6 0	5 4	4 9	4 5	4 8	4 4	4 0	3 7	2 4			
1 . 5m	0	m	0	m	4 . 0	8 2	7 5	7 0	6 4	7 6	7 0	6 4	5 9	6 3	5 9	5 4	5 0	5 2	4 8	4 5	4 1	2 8	
2	0		0		5 . 0	8 5	7 9	7 4	6 9	7 8	7 3	6 8	6 4	6 6	6 2	5 8	5 4	5 1	4 8	4 5	3 0		
2 . 5	0		0		7 . 0	8 8	8 3	7 9	7 5	8 1	7 7	7 3	7 0	6 9	6 5	6 2	5 9	5 7	5 4	5 2	4 9	3 4	
3	0		0		1 0 . 0	9 0	8 7	8 3	8 0	8 4	8 0	7 7	7 4	7 1	6 8	6 6	6 4	5 9	5 7	5 5	5 3	3 8	

