

屋内照明器具特性	
品番 (品名)	X F L 3 2 6 E Z
光源	LDL40S. N / 14 / 26 (2 6 0 0 A) × 2 2 6 0 0 . 0 l m
管理番号	K 0 1 2 6 6 4 7 (5) D B 1
B Z 分類	B Z 3 / 0 . 7 / B Z 2

器具効率		63 %	反射率	天井	80 %				70 %				50 %				30 %				0 %
				壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
上方光束		0 %		床	10 %				10 %				10 %				10 %				0 %
下方光束		63 %	室指数	照明率 (X0.01) ZCM																	
保守率		良 中 否	0.81	0.6	40	34	30	27	40	34	29	27	38	33	29	27	37	32	29	26	25
			0.77	0.8	47	42	38	35	47	41	37	35	45	40	37	34	44	40	37	34	33
			1.0	52	46	43	40	51	46	42	40	49	45	42	40	48	44	42	39	38	
			0.68	1.25	55	50	47	44	54	50	47	44	53	49	46	44	51	48	46	44	42
下方投影面積		cm ²	1.5	57	53	50	47	56	53	50	47	55	52	49	47	53	51	48	46	45	
			等価発光面積		cm ²	2.0	60	57	54	52	59	56	54	51	57	55	53	51	56	54	52
取付高さ	器具間隔最大限		2.5	62	59	57	55	61	58	56	54	59	57	55	54	58	56	54	53	52	
	横方向 (A) 縦方向 (B)		3.0	63	60	58	57	62	60	58	56	60	58	57	55	59	57	56	55	53	
1.5m	2.4 m	2.01 m	4.0	64	62	61	59	63	62	60	59	62	60	59	58	60	59	58	57	56	
2	3.19	2.52	5.0	65	63	62	61	64	63	61	60	63	61	60	59	61	60	59	58	57	
2.5	3.98	3.05	7.0	66	65	64	63	65	64	63	62	64	63	62	61	62	61	61	60	58	
3	4.76	3.58	10.0	67	66	65	64	66	65	64	64	64	64	63	63	63	62	62	61	60	

