

屋内照明器具特性

品番 (品名)	XS Z P 1 5 6 7 N	
光源	LLD2411NCB1 ×1	500.0 l m
管理番号	K0191897 (0) DB 1	
B Z 分類	B Z 1	

器具効率	100 %	天井	80 %				70 %				50 %				30 %				0 %				
			壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %			
上方光束	0 %	床	10 %				10 %				10 %				10 %				0 %				
下方光束	100 %	室指数	照明率 (X 0 . 0 1)																Z C M				
保守率	良	0.69	0.6	89	84	81	78	88	83	80	78	87	83	80	78	86	82	80	78	77			
	中	0.67	0.8	93	89	86	83	93	88	85	83	91	88	85	83	90	87	85	83	82			
	否	0.63	1.0	96	92	89	87	95	92	89	87	94	91	88	86	92	90	88	86	85			
下方投影面積	c m ²	等価発光面積	c m ²	1.25	98	95	92	90	98	94	92	90	96	93	91	89	95	92	90	89	87		
				1.5	100	97	94	92	99	96	94	92	97	95	93	91	96	94	92	91	89	89	
取付高さ	器具間隔最大限		H m	0.78 H m	0.78 H m	2.5	103	101	99	97	102	100	98	97	100	99	97	96	99	97	96	95	93
	横方向 (A)	縦方向 (B)				3.0	104	102	100	99	103	101	100	98	101	100	98	97	99	98	97	96	94
H m	0.78 H m	0.78 H m	4.0	105	104	102	101	104	103	101	100	102	101	100	99	100	99	98	98	95	95		
			5.0	106	105	103	102	105	104	103	102	103	102	101	100	101	100	99	99	96	96		
			7.0	107	106	105	104	105	105	104	103	103	103	102	101	101	100	100	97	97			
			10.0	107	106	106	105	106	105	105	104	104	103	103	102	102	101	101	101	98	98		

