

| 屋内照明器具特性 |                              |
|----------|------------------------------|
| 品番 (品名)  | XNW2 0 3 0 WN                |
| 光源       | LED5000_85_1500 x1 1500.0 lm |
| 管理番号     | K0167853 ( 0 ) DB 1          |
| BZ分類     | BZ1                          |

| 器具効率   |          | 100 %<br>上方光束<br>0 %<br>下方光束 | 天井<br>壁<br>床     | 80 %              |     |     |     | 70 % |     |     |     | 50 % |     |     |     | 30 % |    |    |    | 0 % |    |    |  |
|--------|----------|------------------------------|------------------|-------------------|-----|-----|-----|------|-----|-----|-----|------|-----|-----|-----|------|----|----|----|-----|----|----|--|
|        |          |                              |                  | 70                | 50  | 30  | 10  | 70   | 50  | 30  | 10  | 70   | 50  | 30  | 10  | 70   | 50 | 30 | 10 | 0 % |    |    |  |
|        |          |                              |                  | 10 %              |     |     |     | 10 % |     |     |     | 10 % |     |     |     | 10 % |    |    |    | 0 % |    |    |  |
|        |          | 100 %                        | 室指数              | 照明率 ( X0.01 ) ZCM |     |     |     |      |     |     |     |      |     |     |     |      |    |    |    |     |    |    |  |
| 保守率    |          | 良<br>中<br>否                  | 0.83             | 0.6               | 76  | 69  | 64  | 60   | 75  | 68  | 64  | 60   | 74  | 68  | 63  | 60   | 72 | 67 | 63 | 60  | 59 |    |  |
|        |          |                              | 0.81             | 0.8               | 84  | 77  | 72  | 69   | 83  | 77  | 72  | 69   | 81  | 76  | 72  | 69   | 80 | 75 | 71 | 68  | 67 |    |  |
|        |          |                              | 0.77             | 1.0               | 89  | 83  | 78  | 75   | 88  | 82  | 78  | 75   | 86  | 81  | 77  | 74   | 84 | 80 | 77 | 74  | 72 |    |  |
|        |          |                              |                  | 1.25              | 93  | 87  | 83  | 80   | 91  | 87  | 83  | 80   | 89  | 85  | 82  | 79   | 88 | 84 | 81 | 79  | 77 |    |  |
| 下方投影面積 |          | c m <sup>2</sup>             | 1.5              | 95                | 90  | 87  | 84  | 94   | 90  | 86  | 83  | 92   | 88  | 85  | 83  | 90   | 87 | 84 | 82 | 81  |    |    |  |
| 等価発光面積 |          |                              | c m <sup>2</sup> | 2.0               | 98  | 95  | 91  | 89   | 97  | 94  | 91  | 88   | 95  | 92  | 90  | 88   | 93 | 91 | 89 | 87  | 85 |    |  |
| 取付高さ   | 器具間隔最大限  |                              | 2.5              | 100               | 97  | 94  | 92  | 99   | 96  | 94  | 92  | 97   | 95  | 92  | 91  | 95   | 93 | 91 | 90 | 88  |    |    |  |
|        | 横方向 (A)  |                              | 縦方向 (B)          | 3.0               | 102 | 99  | 96  | 94   | 101 | 98  | 96  | 94   | 98  | 96  | 94  | 93   | 96 | 95 | 93 | 92  | 89 |    |  |
| H m    | 0.71 H m |                              |                  | 0.71 H m          | 4.0 | 103 | 101 | 99   | 97  | 102 | 100 | 98   | 97  | 100 | 98  | 97   | 95 | 98 | 96 | 95  | 94 | 92 |  |
|        |          |                              | 5.0              | 104               | 102 | 101 | 99  | 103  | 101 | 100 | 99  | 101  | 99  | 98  | 97  | 99   | 98 | 97 | 96 | 93  |    |    |  |
|        |          |                              | 7.0              | 105               | 104 | 103 | 102 | 104  | 103 | 102 | 101 | 102  | 101 | 100 | 99  | 100  | 99 | 98 | 98 | 95  |    |    |  |
|        |          |                              | 10.0             | 106               | 105 | 104 | 103 | 105  | 104 | 103 | 102 | 103  | 102 | 101 | 101 | 100  | 99 | 99 | 99 | 96  |    |    |  |

