

屋内照明器具特性	
品番 (品名)	YYY41000
光源	L L D 3 0 2 0 C U 1 × 2 6 1 5 . 0 l m
管理番号	K 0 1 9 4 4 5 2 (1) D 1
B Z 分類	B Z 1

器具効率		5 7 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %		
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %		
上方光束		2 8 %		床	1 0 %				1 0 %				1 0 %				1 0 %				0 %		
下方光束		2 9 %	室指数	照明率 (X 0 . 0 1) Z C M																			
保守率		良	0 . 6 3	0 . 6	4 0	3 6	3 3	3 1	3 8	3 4	3 2	3 1	3 4	3 2	3 0	2 9	3 1	2 9	2 8	2 7	2 5		
		中	0 . 6	0 . 8	4 3	3 9	3 7	3 5	4 1	3 7	3 5	3 4	3 6	3 4	3 3	3 1	3 2	3 1	3 0	2 9	2 6		
		否	1 . 0	4 5	4 2	3 9	3 7	4 2	4 0	3 7	3 6	3 8	3 6	3 4	3 3	3 3	3 2	3 1	3 1	2 7			
		0 . 5 6	1 . 2 5	4 7	4 4	4 1	4 0	4 4	4 2	4 0	3 8	3 9	3 7	3 6	3 5	3 4	3 3	3 2	3 2	2 7			
下方投影面積		c m ²	1 . 5	4 8	4 5	4 3	4 1	4 5	4 3	4 1	4 0	4 0	3 8	3 7	3 6	3 5	3 4	3 3	3 3	2 7			
等価発光面積			c m ²	2 . 0	5 0	4 8	4 6	4 4	4 7	4 5	4 3	4 2	4 1	4 0	3 9	3 8	3 6	3 5	3 4	3 4	2 8		
取付 高さ	器具間隔最大限		2 . 5	5 1	4 9	4 8	4 6	4 8	4 6	4 5	4 4	4 2	4 1	4 0	3 9	3 6	3 6	3 5	3 5	2 8			
	横方向 (A) 縦方向 (B)		3 . 0	5 2	5 0	4 9	4 7	4 9	4 7	4 6	4 5	4 3	4 2	4 1	4 0	3 7	3 6	3 6	3 5	2 8			
H m	0 . 3 2 H m	0 . 3 2 H m	4 . 0	5 3	5 2	5 0	4 9	5 0	4 8	4 7	4 7	4 3	4 2	4 2	4 1	3 7	3 7	3 6	3 6	2 9			
			5 . 0	5 4	5 2	5 1	5 1	5 0	4 9	4 8	4 8	4 4	4 3	4 2	4 2	3 7	3 7	3 7	3 7	2 9			
			7 . 0	5 4	5 3	5 3	5 2	5 1	5 0	4 9	4 9	4 4	4 4	4 3	4 3	3 8	3 8	3 7	3 7	2 9			
			1 0 . 0	5 5	5 4	5 4	5 3	5 1	5 1	5 0	5 0	4 4	4 4	4 4	4 4	3 8	3 8	3 8	3 8	2 9			

