

屋内照明器具特性

品番（品名）	X Y 2 8 9 6 K
光源	L D T 6 L - G - E 1 7 / S / T 6 x 1 8 1 0 . 0 l m
管理番号	K 0 1 7 6 8 5 2 (2) D R 1
B Z 分類	B Z 1 0

器具効率		4 1 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
上方光束		1 7 %	室 指 数	床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
下方光束		2 4 %		照 明 率 (X 0 . 0 1) Z C M																	
保守率	良	0 . 6 3	0 . 6	1 7	1 2	8	5	1 6	1 1	7	5	1 3	9	6	4	1 0	7	5	3	1	
	中	0 . 6	0 . 8	2 0	1 5	1 1	8	1 9	1 4	1 0	7	1 5	1 1	8	6	1 2	9	7	5	2	
	否	0 . 5 6	1 . 0	2 3	1 7	1 3	1 0	2 1	1 6	1 2	1 0	1 7	1 3	1 0	8	1 4	1 1	8	6	3	
下方投影面積		c m ²	1 . 2 5	2 5	2 0	1 6	1 3	2 3	1 8	1 5	1 2	1 9	1 5	1 2	1 0	1 5	1 2	1 0	8	5	
等価発光面積			c m ²	1 . 5	2 7	2 2	1 8	1 5	2 5	2 0	1 7	1 4	2 1	1 7	1 4	1 2	1 7	1 4	1 2	1 0	6
			2 . 0	2 9	2 5	2 1	1 8	2 7	2 3	2 0	1 7	2 3	2 0	1 7	1 5	1 9	1 6	1 4	1 2	8	
取付 高さ	器具間隔最大限		2 . 5	3 1	2 7	2 4	2 1	2 9	2 5	2 2	2 0	2 4	2 1	1 9	1 7	2 0	1 8	1 6	1 4	9	
	横方向 (A) 縦方向 (B)		3 . 0	3 2	2 9	2 6	2 3	3 0	2 7	2 4	2 1	2 5	2 3	2 0	1 8	2 1	1 9	1 7	1 5	1 1	
H m	0 . 0 0 H m	0 . 0 0 H m	4 . 0	3 4	3 1	2 8	2 6	3 2	2 9	2 6	2 4	2 7	2 5	2 3	2 1	2 2	2 1	1 9	1 8	1 3	
			5 . 0	3 5	3 2	3 0	2 8	3 3	3 0	2 8	2 6	2 8	2 6	2 4	2 3	2 3	2 2	2 1	1 9	1 4	
			7 . 0	3 6	3 4	3 2	3 1	3 4	3 2	3 0	2 9	2 9	2 8	2 6	2 5	2 5	2 4	2 2	2 1	1 6	
			1 0 . 0	3 7	3 6	3 4	3 3	3 5	3 4	3 2	3 1	3 0	2 9	2 8	2 7	2 6	2 5	2 4	2 3	1 7	

