

- Diagram illustrating that blowing (ブローイング) and glass wool (グラスウール) are not applicable for this type of insulation. The diagram shows a cross-section of a wall with insulation. A large 'X' is placed over the insulation area, indicating that these methods are not suitable. The text below the diagram reads: ブローイング施工不可 (Blowing construction not possible) and グラスウール施工不可 (Glass wool construction not possible).

Diagram illustrating the minimum distance between the device and the object being irradiated. The device is positioned above the object, with a vertical double-headed arrow indicating the distance. The text next to the arrow states: 近接限度距離 30 cm 以上 (Minimum approach distance 30 cm or more). The object is labeled 被照射物 (Irradiated object).

2-12×20
ボルト取付用

170

電源ユニット


ダブルナット方式
にて位置決め

170

45~55

72~76

埋込穴寸法
 $\varnothing 200 \pm 2$



LED電源ユニット

220
209.5
39.5
6.5

3-4×7長穴
3-4×6長穴

アース付端子台 (送り付) 20A以下

42

調光信号線用端子 (送り可能)

取付金具は5~25mm
の天井に取付可能です

口出し線
約230

□出し線
約230

LED 3 4
Ø 220

ホワイ ト マンセル N9.5		7	放 熱 板	アルミ板 (t1.0)		品 名 ダウ ン ライ ト XND7581SW
器 具 光 束	7800lm	6	補 助 反 射 板	アルミ板 (t1.0)	銀 色 鏡 面 仕 上	
L E D	白 色 (4000K Ra85)	5	天 板	亜鉛鋼板 (t1.0)		
配 光	拡 散 タ イ プ	4	レ ン ズ	ア ク リ ル	透 明	
器 具 質 量	1.6kg (灯 具 : 1.2kg、電 源 : 0.4kg)	3	反 射 板	PBT樹 脂	ホ ワ イ ト	
特 記 事 項		2	本 体	アルミ板 (t3.0)		鶴 鈴 池 田 木 田
		1	枠	鋼 板 (t0.8)	ホ ワ イ ト 半 つ や 消 し ポ リ エ ス テ ル 粉 体 塗 装	
		部 番	部 品 名	材 質 ・ 素 材 厚	備 考	パ ナ ソ ニ ッ ク 株 式 有 限 公 司

