

- Diagram illustrating that blowing (ブローイング) and glass wool (グラスウール) are not applicable for this type of insulation. The diagram shows a cross-section of a wall with insulation. A large 'X' is placed over the insulation area, indicating that these methods are not suitable. The text below the diagram reads: ブローイング施工不可 (Blowing construction not possible) and グラスウール施工不可 (Glass wool construction not possible).

電源線は断熱材の上を通してください。

埋込穴寸法
 $\varnothing 125^{+2}_{-0}$

-

Diagram illustrating the installation of a power supply unit (電源) and a ceiling material (天井材). The power supply unit is shown mounted on a wall, and the ceiling material is shown below it. A dimension line indicates a minimum clearance of 105mm (105mm以上) between the power supply unit and the ceiling material.

LED電源ユニット

245

234.5

49

3-4×7長穴

3-4×6長穴

56

約200mm

アース付端子台（送り付）20A以下

取付パネは5~25mm
の天井に取付可能です

取外し溝

4

1

60

Ø150

施工時 必要 85以上

ホワイト マンセル N9.5

器具光束	1055lm	6	補助反射板	亜鉛銅板(t0.4)	ホワイト半つや消し ポリエステル粉体塗装	品 名 ダウンライト XND1050WNR Y9
LED	昼白色(5000K Ra85)	5	LED			
配 光	広角タイプ	4	レンズ	アクリル	透明	
器具質量	0.8kg (灯具:0.3kg、電源:0.5kg)	3	反射板	PBT樹脂	ホワイト	
特記事項		2	本体	FM材(t2.5) (塗装アルミ合金)	白色	上 岡 池
		1	枠	亜鉛銅板(t0.5)	ホワイト半つや消し ポリエステル粉体塗装	田 田 田
		部 番	部 品 名	材質・素材厚	備 考	パナソニック株式会社