

屋内照明器具特性	
品番 (品名)	L G B 8 1 5 8 8
光源	L G B 8 1 5 8 8 - 0 D E G (H 1) × 1 7 7 0 . 0 l m
管理番号	K 0 1 3 6 1 1 2 (0) D R 1
B Z 分類	B Z 6

器具効率		1 0 0 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1)																Z C M
保守率		良 中 否	0 . 6 7	0 . 6	4 8	3 6	2 9	2 4	4 4	3 4	2 7	2 2	3 7	2 9	2 3	1 9	3 1	2 4	2 0	1 7	1 1
			0 . 6 3	0 . 8	5 7	4 5	3 8	3 2	5 2	4 2	3 5	3 0	4 4	3 6	3 0	2 6	3 6	3 0	2 6	2 2	1 6
			0 . 5 6	1 . 0	6 3	5 2	4 4	3 8	5 8	4 8	4 1	3 6	4 8	4 1	3 6	3 1	4 0	3 4	3 0	2 7	1 9
				1 . 2 5	6 8	5 8	5 1	4 5	6 3	5 4	4 7	4 2	5 3	4 6	4 1	3 7	4 3	3 8	3 4	3 1	2 2
下方投影面積		c m ²	1 . 5	7 2	6 3	5 6	5 0	6 6	5 8	5 2	4 7	5 6	5 0	4 5	4 1	4 6	4 1	3 8	3 4	2 5	
			等価発光面積	c m ²	2 . 0	7 7	6 9	6 3	5 8	7 1	6 4	5 9	5 4	6 0	5 5	5 0	4 7	5 0	4 6	4 2	4 0
取付高さ	器具間隔最大限		2 . 5	8 1	7 4	6 8	6 3	7 5	6 8	6 3	5 9	6 3	5 8	5 4	5 1	5 2	4 9	4 6	4 3	3 1	
	横方向 (A) 縦方向 (B)		3 . 0	8 3	7 7	7 2	6 7	7 7	7 1	6 7	6 3	6 5	6 1	5 7	5 4	5 4	5 1	4 8	4 6	3 3	
1 . 5m	1 . 1 8 m	1 . 9 6 m	4 . 0	8 6	8 1	7 7	7 3	8 0	7 5	7 1	6 8	6 8	6 5	6 1	5 9	5 7	5 4	5 2	5 0	3 6	
2	1 . 5 8	2 . 5 7	5 . 0	8 8	8 4	8 0	7 6	8 2	7 8	7 5	7 1	7 0	6 7	6 4	6 2	5 8	5 6	5 4	5 2	3 8	
2 . 5	1 . 9 8	3 . 1 8	7 . 0	9 0	8 7	8 4	8 1	8 4	8 1	7 8	7 6	7 2	7 0	6 8	6 6	6 0	5 9	5 7	5 5	4 1	
3	2 . 3 8	3 . 7 9	1 0 . 0	9 2	9 0	8 8	8 5	8 6	8 4	8 2	8 0	7 4	7 2	7 0	6 9	6 2	6 1	5 9	5 8	4 3	

