

| 屋内照明器具特性 |                          |
|----------|--------------------------|
| 品番 (品名)  | L G B 8 1 0 0 6          |
| 光源       | LLD4000LCT1 ×1 845.0 l m |
| 管理番号     | K0190528 ( 0 ) DR 1      |
| B Z 分類   | BZ5 / 0.7 / BZ4          |

| 器具効率   |         | 40 %             | 反射率              | 天井            | 80 % |      |    |    | 70 % |    |    |    | 50 % |    |    |    | 30 % |    |    |    | 0 % |    |    |
|--------|---------|------------------|------------------|---------------|------|------|----|----|------|----|----|----|------|----|----|----|------|----|----|----|-----|----|----|
|        |         |                  |                  | 壁             | 70   | 50   | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 0 % |    |    |
|        |         |                  |                  | 床             | 10 % |      |    |    | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 0 % |    |    |
| 上方光束   |         | 20 %             | 室指数              | 照明率 ( X0.01 ) |      |      |    |    |      |    |    |    |      |    |    |    |      |    |    |    | Z   | C  | M  |
| 下方光束   |         | 20 %             |                  |               |      |      |    |    |      |    |    |    |      |    |    |    |      |    |    |    |     |    |    |
| 保守率    |         | 良<br>中<br>否      | 0.63             | 0.6           | 20   | 15   | 13 | 11 | 18   | 14 | 12 | 10 | 16   | 13 | 10 | 9  | 13   | 11 | 9  | 8  | 6   |    |    |
|        |         |                  | 0.6              | 0.8           | 24   | 20   | 17 | 15 | 22   | 18 | 16 | 14 | 19   | 16 | 14 | 12 | 16   | 13 | 12 | 11 | 8   |    |    |
|        |         |                  | 0.56             | 1.0           | 26   | 22   | 20 | 17 | 24   | 21 | 18 | 16 | 21   | 18 | 16 | 15 | 17   | 15 | 14 | 13 | 10  |    |    |
|        |         |                  |                  | 1.25          | 29   | 25   | 22 | 20 | 26   | 23 | 21 | 19 | 23   | 20 | 18 | 17 | 19   | 17 | 16 | 15 | 11  |    |    |
| 下方投影面積 |         | c m <sup>2</sup> | 1.5              | 30            | 27   | 24   | 22 | 28 | 25   | 23 | 21 | 24 | 22   | 20 | 19 | 20 | 18   | 17 | 16 | 12 |     |    |    |
| 等価発光面積 |         |                  | c m <sup>2</sup> | 2.0           | 32   | 30   | 27 | 26 | 30   | 28 | 26 | 24 | 26   | 24 | 22 | 21 | 21   | 20 | 19 | 18 | 14  |    |    |
| 取付高さ   | 器具間隔最大限 |                  |                  | 2.5           | 33   | 31   | 29 | 28 | 31   | 29 | 27 | 26 | 27   | 25 | 24 | 23 | 22   | 21 | 20 | 20 | 15  |    |    |
|        |         | 横方向 ( A )        |                  | 縦方向 ( B )     |      | 3.0  | 34 | 32 | 31   | 29 | 32 | 30 | 29   | 27 | 27 | 26 | 25   | 24 | 23 | 22 | 21  | 21 | 16 |
| H m    |         | 0.00 H m         |                  | 1.67 H m      |      | 4.0  | 35 | 34 | 33   | 31 | 33 | 32 | 30   | 29 | 28 | 27 | 26   | 26 | 24 | 23 | 23  | 22 | 17 |
|        |         |                  |                  |               |      | 5.0  | 36 | 35 | 34   | 33 | 34 | 33 | 32   | 31 | 29 | 28 | 27   | 27 | 24 | 24 | 23  | 23 | 17 |
|        |         |                  |                  |               |      | 7.0  | 37 | 36 | 35   | 34 | 34 | 34 | 33   | 32 | 30 | 29 | 28   | 28 | 25 | 25 | 24  | 24 | 18 |
|        |         |                  |                  |               |      | 10.0 | 38 | 37 | 36   | 36 | 35 | 34 | 34   | 33 | 30 | 30 | 29   | 29 | 26 | 25 | 25  | 25 | 18 |

