

屋内照明器具特性	
品番 (品名)	L G B 8 1 0 1 1
光源	L L D 2 0 0 0 1 C Q 1 × 1 5 3 1 . 0 l m
管理番号	K 0 1 7 6 4 2 6 (0) D R 1
B Z 分類	B Z 5 / 0 . 7 / B Z 4

器具効率		8 6 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否	0 . 6 7	0 . 6	4 9	3 9	3 3	2 8	4 8	3 9	3 2	2 8	4 6	3 8	3 2	2 8	4 4	3 7	3 2	2 8	2 6
			0 . 6 3	0 . 8	5 8	4 9	4 2	3 7	5 7	4 8	4 2	3 7	5 5	4 7	4 1	3 7	5 3	4 6	4 1	3 7	3 5
			0 . 5 6	1 . 0	6 4	5 5	4 9	4 4	6 3	5 4	4 8	4 4	6 0	5 3	4 8	4 3	5 8	5 2	4 7	4 3	4 1
				1 . 2 5	6 9	6 1	5 5	5 0	6 8	6 0	5 5	5 0	6 5	5 9	5 4	5 0	6 3	5 7	5 3	4 9	4 7
下方投影面積		c m ²	1 . 5	7 3	6 5	6 0	5 5	7 1	6 4	5 9	5 5	6 9	6 3	5 8	5 4	6 6	6 1	5 7	5 4	5 2	
等価発光面積			c m ²	2 . 0	7 7	7 1	6 6	6 2	7 6	7 0	6 6	6 2	7 3	6 9	6 5	6 1	7 1	6 7	6 4	6 1	5 9
取付高さ	器具間隔最大限		2 . 5	8 0	7 5	7 1	6 7	7 9	7 4	7 0	6 7	7 6	7 2	6 9	6 6	7 4	7 1	6 8	6 5	6 3	
	横方向 (A) 縦方向 (B)		3 . 0	8 2	7 8	7 4	7 1	8 1	7 7	7 3	7 0	7 9	7 5	7 2	6 9	7 6	7 3	7 1	6 8	6 6	
H m	1 . 2 6 H m 1 . 2 6 H m		4 . 0	8 5	8 1	7 8	7 6	8 4	8 0	7 8	7 5	8 1	7 9	7 6	7 4	7 9	7 7	7 5	7 3	7 1	
			5 . 0	8 6	8 4	8 1	7 9	8 5	8 3	8 0	7 8	8 3	8 1	7 9	7 7	8 1	7 9	7 7	7 6	7 3	
			7 . 0	8 8	8 6	8 4	8 2	8 7	8 5	8 3	8 2	8 5	8 3	8 2	8 0	8 3	8 1	8 0	7 9	7 7	
			1 0 . 0	9 0	8 8	8 7	8 5	8 8	8 7	8 6	8 5	8 6	8 5	8 4	8 3	8 4	8 3	8 2	8 2	7 9	

