

屋内照明器具特性	
品番 (品名)	L R D 9 2 0 1
光源	L L D 4 0 4 0 2 C Q 1 (K A K U S A N) × 1 8 6 0 . 0 1 m
管理番号	K 0 1 8 4 5 3 8 (0) D R 1
B Z 分類	B Z 2 / 8 . 5 / B Z 1

器具効率		3 6 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %	
上方光束		0 %	室指数	照明率 (X 0 . 0 1)																		Z C M
下方光束		3 6 %																				
保守率		良 中 否	0 . 6 3	0 . 6	2 5	2 1	1 9	1 8	2 4	2 1	1 9	1 8	2 4	2 1	1 9	1 8	2 3	2 1	1 9	1 8	1 7	
			0 . 6	0 . 8	2 8	2 5	2 3	2 2	2 8	2 5	2 3	2 1	2 7	2 4	2 3	2 1	2 6	2 4	2 3	2 1	2 1	
			0 . 5 6	1 . 0	3 0	2 8	2 6	2 4	3 0	2 7	2 5	2 4	2 9	2 7	2 5	2 4	2 8	2 6	2 5	2 4	2 3	
				1 . 2 5	3 2	3 0	2 8	2 7	3 2	2 9	2 8	2 6	3 1	2 9	2 7	2 6	3 0	2 8	2 7	2 6	2 5	
下方投影面積		c m ²	1 . 5	3 3	3 1	2 9	2 8	3 3	3 1	2 9	2 8	3 2	3 0	2 9	2 8	3 1	3 0	2 9	2 8	2 7		
等価発光面積			c m ²	2 . 0	3 5	3 3	3 2	3 0	3 4	3 3	3 1	3 0	3 3	3 2	3 1	3 0	3 3	3 1	3 1	3 0	2 9	
取付高さ	器具間隔最大限		2 . 5	3 5	3 4	3 3	3 2	3 5	3 4	3 3	3 2	3 4	3 3	3 2	3 1	3 3	3 2	3 2	3 1	3 0		
	横方向 (A)		縦方向 (B)	3 . 0	3 6	3 5	3 4	3 3	3 6	3 5	3 4	3 3	3 5	3 4	3 3	3 2	3 4	3 3	3 3	3 2	3 1	
H m	0 . 9 7 H m	0 . 9 7 H m	4 . 0	3 7	3 6	3 5	3 4	3 6	3 5	3 5	3 4	3 5	3 5	3 4	3 4	3 5	3 4	3 4	3 3	3 2		
			5 . 0	3 7	3 6	3 6	3 5	3 7	3 6	3 5	3 5	3 6	3 5	3 5	3 4	3 5	3 5	3 4	3 4	3 3		
			7 . 0	3 8	3 7	3 7	3 6	3 7	3 7	3 6	3 6	3 6	3 6	3 6	3 5	3 6	3 5	3 5	3 5	3 4		
			1 0 . 0	3 8	3 8	3 7	3 7	3 8	3 7	3 7	3 7	3 7	3 7	3 6	3 6	3 6	3 6	3 5	3 5	3 4		

