

屋内照明器具特性	
品番 (品名)	L R D 9 2 0 1
光源	L L D 2 0 2 0 L C T 1 × 1 4 6 0 . 0 l m
管理番号	K 0 1 9 0 4 7 9 (0) D R 1
B Z 分類	B Z 1

器具効率		7 2 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %		
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %		
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %		
上方光束		0 %	室指数	照明率 (X 0 . 0 1)																		Z C M	
下方光束		7 2 %																					
保守率		良	0 . 6 3	0 . 6	5 9	5 4	5 1	4 9	5 8	5 4	5 1	4 9	5 7	5 4	5 1	4 9	5 6	5 3	5 1	4 9	4 8		
		中	0 . 6	0 . 8	6 3	5 9	5 6	5 4	6 3	5 9	5 6	5 4	6 2	5 8	5 6	5 4	6 1	5 8	5 6	5 4	5 3		
		否		1 . 0	6 6	6 2	6 0	5 8	6 5	6 2	6 0	5 8	6 4	6 1	5 9	5 7	6 3	6 1	5 9	5 7	5 6		
			0 . 5 6	1 . 2 5	6 8	6 5	6 3	6 1	6 8	6 5	6 2	6 1	6 6	6 4	6 2	6 0	6 5	6 3	6 1	6 0	5 9		
下方投影面積		c m ²		1 . 5	7 0	6 7	6 5	6 3	6 9	6 7	6 4	6 3	6 8	6 6	6 4	6 2	6 7	6 5	6 3	6 2	6 1		
等価発光面積		c m ²		2 . 0	7 2	6 9	6 8	6 6	7 1	6 9	6 7	6 6	7 0	6 8	6 6	6 5	6 8	6 7	6 6	6 4	6 3		
取付 高さ	器具間隔最大限			2 . 5	7 3	7 1	6 9	6 8	7 2	7 0	6 9	6 7	7 1	6 9	6 8	6 7	6 9	6 8	6 7	6 6	6 5		
	横方向 (A)		縦方向 (B)	3 . 0	7 4	7 2	7 0	6 9	7 3	7 1	7 0	6 9	7 1	7 0	6 9	6 8	7 0	6 9	6 8	6 7	6 6		
H m	0 . 4 1 H m	0 . 4 1 H m	4 . 0	7 5	7 3	7 2	7 1	7 4	7 3	7 1	7 0	7 2	7 1	7 0	6 9	7 1	7 0	6 9	6 9	6 7			
			5 . 0	7 5	7 4	7 3	7 2	7 4	7 3	7 2	7 2	7 3	7 2	7 1	7 0	7 1	7 1	7 0	6 9	6 8			
			7 . 0	7 6	7 5	7 4	7 3	7 5	7 4	7 4	7 3	7 3	7 3	7 2	7 2	7 2	7 1	7 1	7 0	6 9			
			1 0 . 0	7 6	7 6	7 5	7 5	7 6	7 5	7 4	7 4	7 4	7 3	7 3	7 3	7 2	7 2	7 2	7 1	6 9			

