

屋内照明器具特性		
品番（品名）	X S L G 1 0 6 L S	
光源	L E D 2 7 0 0 _ 7 0 _ 2 2 0 x 1 2 2 0 . 0 l m	
管理番号	K 0 1 6 9 1 7 9 (0) D R 1	
B Z 分類	B Z 5 / 0 . 7 / B Z 4	

器具効率		100 %	反 射 率	天井	80 %				70 %				50 %				30 %				0 %
上方光束		50 %		壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
下方光束		50 %		床	10 %				10 %				10 %				10 %				0 %
			室指数	照明率 (X0.01) ZCM																	
保守率		良 0.63	0.6	50	39	32	27	47	37	30	26	39	32	26	23	33	27	23	20	15	
		中 0.6	0.8	60	49	42	37	55	46	39	35	47	40	35	31	39	34	30	27	21	
		否 0.56	1.0	66	56	49	44	61	53	46	42	52	46	41	37	44	39	35	32	25	
下方投影面積		c m ²	1.25	72	63	56	51	66	59	53	48	57	51	46	43	48	43	40	37	29	
			1.5	75	67	61	56	70	63	58	53	60	55	50	47	50	47	43	41	31	
等価発光面積		c m ²	2.0	81	74	69	64	75	69	64	60	64	60	56	53	54	51	48	46	35	
取付	器具間隔最大限		2.5	84	78	73	69	78	73	69	65	67	63	60	57	56	54	51	49	38	
高さ	横方向 (A)	縦方向 (B)	3.0	86	81	77	73	80	76	72	69	69	66	63	60	58	56	54	52	39	
H m	0.00 H m	1.67 H m	4.0	89	85	82	78	83	79	76	74	71	69	66	64	60	58	57	55	42	
			5.0	91	87	84	82	84	82	79	77	73	71	69	67	61	60	59	57	43	
			7.0	92	90	88	86	86	84	82	80	74	73	71	70	63	62	61	60	45	
			10.0	94	92	91	89	88	86	85	83	76	75	73	72	64	63	63	62	47	

1 0 0 %
5 0 %
5 0 %

反射率	天井	80 %				70 %				50 %				30 %				0 %
	壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
	床	10 %				10 %				10 %				10 %				0 %
室指数		照明率 (X 0.01)																Z C M

保守率

良	0.63
中	0.6
否	0.56

下方投影面積
等価発光面積

取付
高さ

器具間隔最大限	
横方向 (A)	縦方向 (B)

H m

0.00 H _m	1.67 H _m
---------------------	---------------------

