

# 屋内照明器具特性

|         |                                        |  |  |  |  |  |  |  |  |  |           |  |  |  |  |
|---------|----------------------------------------|--|--|--|--|--|--|--|--|--|-----------|--|--|--|--|
| 品番 (品名) | S F 2 6 2 Z                            |  |  |  |  |  |  |  |  |  |           |  |  |  |  |
| 光源      | LDA4L - G - E17 / Z40E / S / W / 2 × 1 |  |  |  |  |  |  |  |  |  | 440.0 l m |  |  |  |  |
| 管理番号    | K0139358 ( 0 ) DB 1                    |  |  |  |  |  |  |  |  |  |           |  |  |  |  |
| BZ分類    | BZ10                                   |  |  |  |  |  |  |  |  |  |           |  |  |  |  |

|        |           |                  |                  |     |      |     |      |     |      |     |      |     |      |     |      |     |      |     |     |     |
|--------|-----------|------------------|------------------|-----|------|-----|------|-----|------|-----|------|-----|------|-----|------|-----|------|-----|-----|-----|
| 器具効率   | 68 %      | 天井               | 80 %             |     |      |     | 70 % |     |      |     | 50 % |     |      |     | 30 % |     |      |     | 0 % |     |
|        |           |                  | 壁                | 70  | 50   | 30  | 10   | 70  | 50   | 30  | 10   | 70  | 50   | 30  | 10   | 70  | 50   | 30  | 10  | 0 % |
|        |           |                  |                  | 床   | 10 % |     |      |     | 10 % |     |      |     | 10 % |     |      |     | 10 % |     |     |     |
| 上方光束   | 39 %      | 室指数              | 照明率 ( X0.01 )    |     |      |     |      |     |      |     |      |     |      |     |      |     |      | ZCM |     |     |
| 下方光束   | 29 %      |                  |                  |     |      |     |      |     |      |     |      |     |      |     |      |     |      |     |     |     |
| 保守率    | 良         | 0.63             | 0.6              | 2.9 | 2.0  | 1.4 | 1.1  | 2.6 | 1.8  | 1.3 | 9    | 2.0 | 1.4  | 1.0 | 7    | 1.5 | 1.1  | 7   | 5   | 1   |
|        | 中         | 0.6              | 0.8              | 3.4 | 2.5  | 1.9 | 1.5  | 3.1 | 2.3  | 1.7 | 1.4  | 2.4 | 1.8  | 1.4 | 1.1  | 1.8 | 1.3  | 1.0 | 8   | 3   |
|        | 否         | 0.56             | 1.0              | 3.8 | 3.0  | 2.3 | 1.9  | 3.4 | 2.7  | 2.1 | 1.7  | 2.7 | 2.1  | 1.7 | 1.3  | 2.0 | 1.6  | 1.2 | 1.0 | 4   |
|        |           |                  | 1.25             | 4.2 | 3.4  | 2.8 | 2.3  | 3.7 | 3.0  | 2.5 | 2.1  | 3.0 | 2.4  | 2.0 | 1.7  | 2.2 | 1.8  | 1.5 | 1.2 | 5   |
| 下方投影面積 |           | c m <sup>2</sup> | 1.5              | 4.4 | 3.7  | 3.1 | 2.6  | 4.0 | 3.3  | 2.8 | 2.4  | 3.2 | 2.7  | 2.3 | 1.9  | 2.4 | 2.0  | 1.7 | 1.4 | 7   |
| 等価発光面積 |           |                  | c m <sup>2</sup> | 2.0 | 4.8  | 4.2 | 3.6  | 3.2 | 4.4  | 3.8 | 3.3  | 2.9 | 3.5  | 3.0 | 2.7  | 2.3 | 2.7  | 2.3 | 2.0 | 1.8 |
| 取付高さ   | 器具間隔最大限   |                  | 2.5              | 5.1 | 4.5  | 4.0 | 3.6  | 4.6 | 4.1  | 3.6 | 3.3  | 3.7 | 3.3  | 3.0 | 2.6  | 2.9 | 2.5  | 2.3 | 2.0 | 1.1 |
|        | 横方向 ( A ) | 縦方向 ( B )        | 3.0              | 5.3 | 4.7  | 4.3 | 3.9  | 4.8 | 4.3  | 3.9 | 3.6  | 3.9 | 3.5  | 3.2 | 2.9  | 3.0 | 2.7  | 2.5 | 2.2 | 1.2 |
| H m    | 0.00 H m  | 0.00 H m         | 4.0              | 5.5 | 5.1  | 4.7 | 4.3  | 5.0 | 4.6  | 4.3 | 4.0  | 4.1 | 3.8  | 3.5 | 3.2  | 3.2 | 3.0  | 2.7 | 2.5 | 1.5 |
|        |           |                  | 5.0              | 5.7 | 5.3  | 5.0 | 4.6  | 5.2 | 4.8  | 4.5 | 4.2  | 4.2 | 4.0  | 3.7 | 3.5  | 3.3 | 3.1  | 2.9 | 2.8 | 1.6 |
|        |           |                  | 7.0              | 5.9 | 5.6  | 5.3 | 5.0  | 5.4 | 5.1  | 4.9 | 4.6  | 4.4 | 4.2  | 4.0 | 3.8  | 3.5 | 3.3  | 3.2 | 3.0 | 1.9 |
|        |           |                  | 10.0             | 6.0 | 5.8  | 5.6 | 5.4  | 5.5 | 5.3  | 5.1 | 5.0  | 4.6 | 4.4  | 4.3 | 4.1  | 3.7 | 3.5  | 3.4 | 3.3 | 2.1 |

