

屋内照明器具特性	
品番 (品名)	NY Y5 6 2 0 8 K+ N T S 9 0 1 5 0
光源	LED3500_85_1595 ×1 1595.0 lm
管理番号	K0149448 (0) DB 1
B Z 分類	B Z 1

器具効率		1 0 0 % 上方光束 0 % 下方光束 1 0 0 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否	0 . 8 1	0 . 6	7 4	6 6	6 0	5 7	7 3	6 5	6 0	5 7	7 1	6 5	6 0	5 7	7 0	6 4	6 0	5 6	5 5
			0 . 7 7	0 . 8	8 2	7 5	7 0	6 7	8 1	7 5	7 0	6 6	8 0	7 4	6 9	6 6	7 8	7 3	6 9	6 6	6 4
			1 . 0	8 8	8 1	7 7	7 3	8 7	8 1	7 6	7 3	8 5	7 9	7 6	7 2	8 3	7 8	7 5	7 2	7 1	
			0 . 6 8	1 . 2 5	9 2	8 6	8 2	7 9	9 1	8 6	8 2	7 8	8 9	8 4	8 1	7 8	8 7	8 3	8 0	7 7	7 6
下方投影面積		c m ²	1 . 5	9 5	9 0	8 6	8 3	9 3	8 9	8 5	8 2	9 1	8 7	8 4	8 2	8 9	8 6	8 3	8 1	7 9	
			等価発光面積		c m ²	2 . 0	9 8	9 4	9 1	8 8	9 7	9 3	9 0	8 8	9 5	9 2	8 9	8 7	9 3	9 0	8 8
取付 高さ	器具間隔最大限		2 . 5	1 0 0	9 7	9 4	9 1	9 9	9 6	9 3	9 1	9 7	9 4	9 2	9 0	9 5	9 3	9 1	8 9	8 7	
	横方向 (A) 縦方向 (B)		3 . 0	1 0 2	9 9	9 6	9 4	1 0 0	9 8	9 5	9 3	9 8	9 6	9 4	9 2	9 6	9 4	9 3	9 1	8 9	
H m	1 . 2 1 H m	1 . 2 1 H m	4 . 0	1 0 3	1 0 1	9 9	9 7	1 0 2	1 0 0	9 8	9 6	1 0 0	9 8	9 7	9 5	9 8	9 6	9 5	9 4	9 1	
			5 . 0	1 0 4	1 0 2	1 0 1	9 9	1 0 3	1 0 1	1 0 0	9 8	1 0 1	9 9	9 8	9 7	9 9	9 8	9 6	9 5	9 3	
			7 . 0	1 0 5	1 0 4	1 0 3	1 0 2	1 0 4	1 0 3	1 0 2	1 0 1	1 0 2	1 0 1	1 0 0	9 9	1 0 0	9 9	9 8	9 7	9 5	
			1 0 . 0	1 0 6	1 0 5	1 0 4	1 0 4	1 0 5	1 0 4	1 0 3	1 0 3	1 0 3	1 0 2	1 0 1	1 0 1	1 0 1	1 0 0	1 0 0	9 9	9 6	

