

屋内照明器具特性	
品番 (品名)	L G B 1 5 1 5 0
光源	L L D 2 0 0 0 1 C Q 1 × 1 5 3 1 . 0 l m
管理番号	K 0 1 8 6 4 8 2 (0) D R 1
B Z 分類	B Z 5

器具効率		5 7 %	反射率	天井	8 0 %					7 0 %					5 0 %					3 0 %					0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %				
				床	1 0 %					1 0 %					1 0 %					1 0 %					0 %
上方光束		2 %	室指数	照明率 (X 0 . 0 1) Z C M																					
下方光束		5 5 %																							
保守率		良 中 否	0 . 6 7	0 . 6	3 3	2 6	2 1	1 8	3 2	2 5	2 1	1 8	3 0	2 5	2 1	1 8	2 9	2 4	2 0	1 8	1 7				
			0 . 6 3	0 . 8	3 8	3 2	2 7	2 4	3 7	3 1	2 7	2 4	3 5	3 0	2 6	2 4	3 4	2 9	2 6	2 3	2 2				
			0 . 5 6	1 . 0	4 2	3 6	3 2	2 8	4 1	3 5	3 1	2 8	3 9	3 4	3 1	2 8	3 7	3 3	3 0	2 7	2 6				
				1 . 2 5	4 5	4 0	3 6	3 2	4 4	3 9	3 5	3 2	4 2	3 8	3 4	3 2	4 0	3 7	3 4	3 1	3 0				
下方投影面積		cm ²	1 . 5	4 8	4 3	3 9	3 6	4 7	4 2	3 8	3 5	4 4	4 0	3 7	3 5	4 2	3 9	3 6	3 4	3 2					
等価発光面積		cm ²	2 . 0	5 1	4 7	4 3	4 0	5 0	4 6	4 3	4 0	4 8	4 4	4 2	3 9	4 6	4 3	4 0	3 8	3 7					
取付高さ	器具間隔最大限		2 . 5	5 3	4 9	4 6	4 4	5 2	4 8	4 6	4 3	5 0	4 7	4 4	4 2	4 8	4 5	4 3	4 1	4 0					
	横方向 (A)	縦方向 (B)	3 . 0	5 4	5 1	4 8	4 6	5 3	5 0	4 8	4 5	5 1	4 9	4 6	4 4	4 9	4 7	4 5	4 4	4 2					
H m	0 . 8 2 H m	0 . 8 2 H m	4 . 0	5 6	5 3	5 1	4 9	5 5	5 3	5 0	4 9	5 3	5 1	4 9	4 8	5 1	4 9	4 8	4 6	4 4					
			5 . 0	5 7	5 5	5 3	5 1	5 6	5 4	5 2	5 1	5 4	5 2	5 1	4 9	5 2	5 1	4 9	4 8	4 6					
			7 . 0	5 8	5 7	5 5	5 4	5 7	5 6	5 4	5 3	5 5	5 4	5 3	5 2	5 3	5 2	5 1	5 1	4 8					
			1 0 . 0	5 9	5 8	5 7	5 6	5 8	5 7	5 6	5 5	5 6	5 5	5 5	5 4	5 4	5 4	5 3	5 2	5 0					

