

屋内照明器具特性	
品番 (品名)	L G B 1 5 3 7 9
光源	L L D 3 0 0 0 C U 1 × 1 7 9 5 . 0 l m
管理番号	K 0 1 7 9 0 3 6 (0) D R 1
B Z 分類	B Z 5

器具効率		7 8 % 上方光束 4 % 下方光束 7 4 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否 0 . 6 7 0 . 6 3 0 . 5 6	0 . 6	4 3	3 3	2 7	2 2	4 1	3 2	2 6	2 2	3 9	3 1	2 6	2 2	3 7	3 0	2 5	2 2	2 0	
			0 . 8	5 0	4 1	3 5	3 0	4 9	4 0	3 4	3 0	4 6	3 9	3 3	2 9	4 4	3 7	3 2	2 9	2 7	
			1 . 0	5 5	4 6	4 0	3 5	5 4	4 6	4 0	3 5	5 1	4 4	3 9	3 5	4 8	4 2	3 8	3 4	3 2	
			1 . 2 5	6 0	5 2	4 6	4 1	5 8	5 1	4 5	4 1	5 5	4 9	4 4	4 0	5 2	4 7	4 3	3 9	3 7	
下方投影面積		c m ²	1 . 5	6 3	5 6	5 0	4 5	6 1	5 5	4 9	4 5	5 8	5 3	4 8	4 4	5 5	5 1	4 7	4 3	4 1	
等価発光面積			c m ²	2 . 0	6 7	6 1	5 6	5 2	6 6	6 0	5 5	5 1	6 3	5 8	5 4	5 0	6 0	5 6	5 2	4 9	4 7
取付 高さ	器具間隔最大限		2 . 5	7 0	6 5	6 0	5 6	6 9	6 4	5 9	5 6	6 5	6 1	5 8	5 5	6 3	5 9	5 6	5 3	5 1	
	横方向 (A) 縦方向 (B)		3 . 0	7 2	6 8	6 3	6 0	7 1	6 6	6 2	5 9	6 8	6 4	6 1	5 8	6 5	6 2	5 9	5 6	5 3	
H m	1 . 1 8 H m	1 . 1 8 H m	4 . 0	7 5	7 1	6 8	6 5	7 3	7 0	6 7	6 4	7 0	6 7	6 5	6 2	6 7	6 5	6 3	6 1	5 8	
			5 . 0	7 6	7 3	7 0	6 8	7 5	7 2	6 9	6 7	7 2	6 9	6 7	6 5	6 9	6 7	6 5	6 3	6 0	
			7 . 0	7 8	7 6	7 4	7 1	7 7	7 5	7 2	7 0	7 4	7 2	7 0	6 9	7 1	7 0	6 8	6 7	6 4	
			1 0 . 0	8 0	7 8	7 6	7 5	7 8	7 7	7 5	7 4	7 5	7 4	7 3	7 1	7 3	7 2	7 1	6 9	6 6	

