

屋内照明器具特性	
品番 (品名)	L G B 1 5 3 9 8
光源	L L D 2 0 2 0 M L C E 1 × 1 4 6 0 . 0 l m
管理番号	K 0 1 7 5 7 5 3 (1) D R 1
B Z 分類	B Z 1

器具効率		8 8 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %	
上方光束		0 %	室指数	照明率 (X 0 . 0 1) Z C M																		
下方光束				8 8 %																		
保守率		良	0 . 6 7	0 . 6	7 5	7 0	6 6	6 4	7 4	6 9	6 6	6 4	7 3	6 9	6 6	6 4	7 2	6 8	6 6	6 4	6 3	
		中	0 . 6 3	0 . 8	8 0	7 5	7 2	7 0	7 9	7 5	7 2	7 0	7 8	7 4	7 2	7 0	7 7	7 3	7 1	6 9	6 8	
		否	0 . 5 6	1 . 0	8 3	7 9	7 6	7 4	8 2	7 8	7 6	7 3	8 1	7 7	7 5	7 3	7 9	7 7	7 5	7 3	7 2	
		1 . 2 5	8 5	8 2	7 9	7 7	8 5	8 1	7 9	7 7	8 3	8 0	7 8	7 6	8 2	7 9	7 7	7 6	7 5			
下方投影面積		c m ²	1 . 5	8 7	8 4	8 1	7 9	8 6	8 3	8 1	7 9	8 5	8 2	8 0	7 9	8 3	8 1	7 9	7 8	7 7		
			2 . 0	8 9	8 7	8 4	8 3	8 8	8 6	8 4	8 2	8 7	8 5	8 3	8 2	8 5	8 3	8 2	8 1	7 9		
取付 高さ	器具間隔最大限		2 . 5	9 0	8 8	8 6	8 5	8 9	8 7	8 6	8 4	8 8	8 6	8 5	8 3	8 6	8 5	8 4	8 3	8 1		
	横方向 (A)	縦方向 (B)	3 . 0	9 1	8 9	8 8	8 6	9 0	8 9	8 7	8 6	8 8	8 7	8 6	8 5	8 7	8 6	8 5	8 4	8 2		
H m	0 . 4 7 H m	0 . 4 7 H m	4 . 0	9 2	9 1	8 9	8 8	9 1	9 0	8 9	8 8	8 9	8 8	8 7	8 6	8 8	8 7	8 6	8 5	8 3		
			5 . 0	9 3	9 2	9 1	9 0	9 2	9 1	9 0	8 9	9 0	8 9	8 8	8 8	8 8	8 8	8 7	8 6	8 4		
			7 . 0	9 4	9 3	9 2	9 1	9 3	9 2	9 1	9 0	9 1	9 0	8 9	8 9	8 9	8 8	8 8	8 7	8 5		
			1 0 . 0	9 4	9 3	9 3	9 2	9 3	9 3	9 2	9 1	9 1	9 1	9 0	9 0	8 9	8 9	8 9	8 8	8 6		

