

屋内照明器具特性	
品番 (品名)	L G B 1 5 3 3 9
光源	L L D 3 0 2 0 M L C B 1 × 1 7 1 5 . 0 l m
管理番号	K 0 1 7 6 3 1 6 (0) D R 1
B Z 分類	B Z 1

器具効率		8 4 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %	
上方光束		0 %	室指数	照明率 (X 0 . 0 1) Z C M																		
下方光束		8 4 %																				
保守率		良	0 . 6 7	0 . 6	7 0	6 5	6 2	5 9	6 9	6 5	6 1	5 9	6 8	6 4	6 1	5 9	6 7	6 3	6 1	5 9	5 8	
		中	0 . 6 3	0 . 8	7 5	7 0	6 7	6 5	7 4	7 0	6 7	6 5	7 3	6 9	6 7	6 5	7 2	6 9	6 6	6 4	6 3	
		否	0 . 5 6	1 . 0	7 8	7 4	7 1	6 9	7 7	7 3	7 1	6 9	7 6	7 3	7 0	6 8	7 5	7 2	7 0	6 8	6 7	
				1 . 2 5	8 1	7 7	7 4	7 2	8 0	7 6	7 4	7 2	7 8	7 5	7 3	7 1	7 7	7 5	7 3	7 1	7 0	
下方投影面積		c m ²		1 . 5	8 2	7 9	7 7	7 5	8 1	7 9	7 6	7 4	8 0	7 7	7 5	7 4	7 8	7 6	7 5	7 3	7 2	
等価発光面積		c m ²		2 . 0	8 4	8 2	8 0	7 8	8 4	8 1	7 9	7 8	8 2	8 0	7 8	7 7	8 0	7 9	7 7	7 6	7 5	
取付 高さ	器具間隔最大限		2 . 5	8 6	8 4	8 2	8 0	8 5	8 3	8 1	8 0	8 3	8 1	8 0	7 9	8 2	8 0	7 9	7 8	7 6		
	横方向 (A) 縦方向 (B)		3 . 0	8 7	8 5	8 3	8 2	8 6	8 4	8 2	8 1	8 4	8 3	8 1	8 0	8 2	8 1	8 0	7 9	7 7		
H m	0 . 4 1 H m	0 . 4 1 H m	4 . 0	8 8	8 6	8 5	8 4	8 7	8 5	8 4	8 3	8 5	8 4	8 3	8 2	8 3	8 2	8 2	8 1	7 9		
			5 . 0	8 8	8 7	8 6	8 5	8 7	8 6	8 5	8 4	8 6	8 5	8 4	8 3	8 4	8 3	8 2	8 2	8 0		
			7 . 0	8 9	8 8	8 7	8 6	8 8	8 7	8 6	8 6	8 6	8 6	8 5	8 4	8 5	8 4	8 3	8 3	8 1		
			1 0 . 0	9 0	8 9	8 8	8 8	8 9	8 8	8 7	8 7	8 7	8 6	8 6	8 5	8 5	8 5	8 4	8 4	8 2		

