

| 屋内照明器具特性 |                             |
|----------|-----------------------------|
| 品番 (品名)  | L G B 1 6 1 2 1             |
| 光源       | LLD4000LCE1 ×1 845.0 l m    |
| 管理番号     | K0176282 ( 0 ) DR 1         |
| B Z 分類   | BZ5 / 0.7 / BZ4 / 6.0 / BZ3 |

| 器具効率     |                     | 73 %             | 反射率    | 天井               | 80 %          |    |    |    | 70 % |    |    |    | 50 % |    |    |    | 30 % |    |    |    | 0 %   |
|----------|---------------------|------------------|--------|------------------|---------------|----|----|----|------|----|----|----|------|----|----|----|------|----|----|----|-------|
|          |                     |                  |        | 壁                | 70            | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 0 %   |
|          |                     |                  |        | 床                | 10 %          |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 0 %   |
|          |                     |                  |        | 室指数              | 照明率 ( X0.01 ) |    |    |    |      |    |    |    |      |    |    |    |      |    |    |    | Z C M |
| 保守率      |                     | 良<br>中<br>否      | 0.67   | 0.6              | 43            | 34 | 28 | 25 | 42   | 34 | 28 | 25 | 40   | 33 | 28 | 24 | 39   | 32 | 28 | 24 | 23    |
|          |                     |                  | 0.63   | 0.8              | 50            | 42 | 37 | 33 | 49   | 42 | 37 | 33 | 47   | 41 | 36 | 33 | 46   | 40 | 36 | 32 | 31    |
|          |                     |                  | 0.56   | 1.0              | 56            | 48 | 43 | 39 | 54   | 48 | 43 | 39 | 52   | 46 | 42 | 38 | 50   | 45 | 41 | 38 | 37    |
|          |                     |                  |        | 1.25             | 60            | 54 | 49 | 45 | 59   | 53 | 48 | 45 | 57   | 52 | 48 | 44 | 55   | 50 | 47 | 44 | 42    |
| 下方投影面積   |                     | c m <sup>2</sup> |        | 1.5              | 63            | 57 | 53 | 49 | 62   | 57 | 52 | 49 | 60   | 55 | 52 | 48 | 58   | 54 | 51 | 48 | 46    |
|          |                     |                  | 等価発光面積 | c m <sup>2</sup> | 2.0           | 67 | 63 | 59 | 55   | 66 | 62 | 58 | 55   | 64 | 60 | 57 | 55   | 62 | 59 | 56 | 54    |
| 取付<br>高さ | 器具間隔最大限             |                  |        | 2.5              | 70            | 66 | 62 | 60 | 69   | 65 | 62 | 59 | 67   | 63 | 61 | 58 | 65   | 62 | 60 | 58 | 56    |
|          | 横方向 ( A ) 縦方向 ( B ) |                  |        | 3.0              | 71            | 68 | 65 | 62 | 70   | 67 | 64 | 62 | 68   | 66 | 63 | 61 | 66   | 64 | 62 | 60 | 59    |
| H m      | 1.28 H m 1.28 H m   |                  |        | 4.0              | 73            | 71 | 68 | 66 | 72   | 70 | 68 | 66 | 70   | 68 | 66 | 65 | 69   | 67 | 65 | 64 | 62    |
|          |                     |                  |        | 5.0              | 75            | 72 | 70 | 69 | 74   | 72 | 70 | 68 | 72   | 70 | 68 | 67 | 70   | 68 | 67 | 66 | 64    |
|          |                     |                  |        | 7.0              | 76            | 74 | 73 | 72 | 75   | 74 | 72 | 71 | 73   | 72 | 71 | 70 | 71   | 70 | 69 | 68 | 66    |
|          |                     |                  |        | 10.0             | 77            | 76 | 75 | 74 | 76   | 75 | 74 | 73 | 74   | 73 | 73 | 72 | 73   | 72 | 71 | 70 | 68    |

