

屋内照明器具特性	
品番 (品名)	XAD3 1 0 1 VK
光源	LLD4000VCB1 ×1 845.0 l m
管理番号	K0175547 (0) DR 1
B Z 分類	BZ4 / 0.7 / BZ3

器具効率		6 4 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %	
上方光束		0 %	室指数	照明率 (X 0 . 0 1)																		Z C M
下方光束		6 4 %																				
保守率		良 中 否	0 . 6 7	0 . 6	3 9	3 2	2 7	2 4	3 8	3 1	2 7	2 4	3 7	3 1	2 7	2 4	3 5	3 0	2 6	2 4	2 3	
			0 . 6 3	0 . 8	4 6	3 9	3 5	3 1	4 5	3 9	3 4	3 1	4 3	3 8	3 4	3 1	4 2	3 7	3 4	3 1	3 0	
			0 . 5 6	1 . 0	5 0	4 4	4 0	3 7	4 9	4 4	4 0	3 6	4 7	4 3	3 9	3 6	4 6	4 2	3 9	3 6	3 5	
				1 . 2 5	5 4	4 8	4 5	4 1	5 3	4 8	4 4	4 1	5 1	4 7	4 4	4 1	4 9	4 6	4 3	4 1	3 9	
下方投影面積		c m ²	1 . 5	5 6	5 1	4 8	4 5	5 5	5 1	4 7	4 5	5 3	5 0	4 7	4 4	5 2	4 9	4 6	4 4	4 3		
等価発光面積		c m ²	2 . 0	5 9	5 6	5 2	5 0	5 8	5 5	5 2	5 0	5 7	5 4	5 1	4 9	5 5	5 3	5 0	4 9	4 7		
取付 高さ	器具間隔最大限		2 . 5	6 1	5 8	5 5	5 3	6 0	5 7	5 5	5 3	5 9	5 6	5 4	5 2	5 7	5 5	5 3	5 1	5 0		
	横方向 (A)	縦方向 (B)	3 . 0	6 3	6 0	5 7	5 5	6 2	5 9	5 7	5 5	6 0	5 8	5 6	5 4	5 8	5 7	5 5	5 4	5 2		
H m	1 . 2 5 H m	1 . 2 5 H m	4 . 0	6 4	6 2	6 0	5 8	6 3	6 1	6 0	5 8	6 2	6 0	5 8	5 7	6 0	5 9	5 7	5 6	5 5		
			5 . 0	6 5	6 3	6 2	6 0	6 4	6 3	6 1	6 0	6 3	6 1	6 0	5 9	6 1	6 0	5 9	5 8	5 6		
			7 . 0	6 6	6 5	6 4	6 3	6 5	6 4	6 3	6 2	6 4	6 3	6 2	6 1	6 2	6 2	6 1	6 0	5 8		
			1 0 . 0	6 7	6 6	6 5	6 4	6 6	6 5	6 5	6 4	6 5	6 4	6 3	6 3	6 3	6 3	6 2	6 2	6 0		

