

屋内照明器具特性	
品番 (品名)	L S P S 9 0 1
光源	L L D 3 0 2 0 M L C E 1 × 1 7 9 5 . 0 l m
管理番号	K 0 1 7 6 3 4 6 (0) D R 1
B Z 分類	B Z 1

器具効率		8 7 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %	
上方光束		0 %	室指数	照明率 (X 0 . 0 1)																		Z C M
下方光束		8 7 %																				
保守率		良 中 否	0 . 6 3	0 . 6	7 4	6 8	6 5	6 3	7 3	6 8	6 5	6 3	7 2	6 8	6 5	6 3	7 1	6 7	6 5	6 3	6 2	
			0 . 6	0 . 8	7 9	7 4	7 1	6 9	7 8	7 4	7 1	6 9	7 7	7 3	7 0	6 8	7 5	7 2	7 0	6 8	6 7	
			0 . 5 6	1 . 0	8 2	7 8	7 5	7 3	8 1	7 7	7 4	7 2	7 9	7 6	7 4	7 2	7 8	7 6	7 3	7 2	7 1	
				1 . 2 5	8 4	8 1	7 8	7 6	8 3	8 0	7 8	7 6	8 2	7 9	7 7	7 5	8 1	7 8	7 6	7 5	7 4	
下方投影面積		c m ²		1 . 5	8 6	8 3	8 0	7 8	8 5	8 2	8 0	7 8	8 3	8 1	7 9	7 7	8 2	8 0	7 8	7 7	7 6	
				2 . 0	8 8	8 5	8 3	8 2	8 7	8 5	8 3	8 1	8 5	8 3	8 2	8 0	8 4	8 2	8 1	8 0	7 8	
取付 高さ	器具間隔最大限			2 . 5	8 9	8 7	8 5	8 4	8 8	8 6	8 5	8 3	8 6	8 5	8 3	8 2	8 5	8 4	8 2	8 1	8 0	
	横方向 (A)	縦方向 (B)		3 . 0	9 0	8 8	8 6	8 5	8 9	8 7	8 6	8 5	8 7	8 6	8 5	8 4	8 6	8 4	8 3	8 3	8 1	
H m	0 . 4 1 H m	0 . 4 1 H m		4 . 0	9 1	8 9	8 8	8 7	9 0	8 9	8 8	8 6	8 8	8 7	8 6	8 5	8 7	8 6	8 5	8 4	8 2	
				5 . 0	9 2	9 0	8 9	8 8	9 1	9 0	8 9	8 8	8 9	8 8	8 7	8 6	8 7	8 6	8 6	8 5	8 3	
				7 . 0	9 2	9 1	9 1	9 0	9 1	9 0	9 0	8 9	8 9	8 9	8 8	8 8	8 8	8 7	8 7	8 6	8 4	
				1 0 . 0	9 3	9 2	9 2	9 1	9 2	9 1	9 1	9 0	9 0	8 9	8 9	8 9	8 8	8 8	8 7	8 7	8 5	

