

| 屋内照明器具特性 |                          |
|----------|--------------------------|
| 品番 (品名)  | LGB16187                 |
| 光源       | LLD2020MLCE1 ×1 460.0 lm |
| 管理番号     | K0185498 (1) DR1         |
| BZ分類     | BZ1                      |

| 器具効率     |           | 91 %             | 反<br>射<br>率 | 天井               | 80 % |    |    |    | 70 % |    |    |    | 50 % |    |    |    | 30 % |    |    |    | 0 % |    |   |  |   |
|----------|-----------|------------------|-------------|------------------|------|----|----|----|------|----|----|----|------|----|----|----|------|----|----|----|-----|----|---|--|---|
|          |           |                  |             | 壁                | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 0 % |    |   |  |   |
|          |           |                  |             | 床                | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 0 % |    |   |  |   |
| 上方光束     |           | 0 %              | 室指数         | 照明率 ( X0.01 )    |      |    |    |    |      |    |    |    |      |    |    |    |      |    |    |    |     | Z  | C |  | M |
| 下方光束     |           | 91 %             |             |                  |      |    |    |    |      |    |    |    |      |    |    |    |      |    |    |    |     |    |   |  |   |
| 保守率      |           | 良<br>中<br>否      | 0.67        | 0.6              | 75   | 70 | 66 | 63 | 75   | 69 | 66 | 63 | 73   | 69 | 65 | 63 | 72   | 68 | 65 | 63 | 62  |    |   |  |   |
|          |           |                  | 0.63        | 0.8              | 81   | 76 | 73 | 70 | 80   | 76 | 72 | 70 | 79   | 75 | 72 | 70 | 78   | 74 | 71 | 69 | 68  |    |   |  |   |
|          |           |                  | 0.56        | 1.0              | 85   | 80 | 77 | 74 | 84   | 80 | 77 | 74 | 82   | 79 | 76 | 74 | 81   | 78 | 75 | 74 | 72  |    |   |  |   |
|          |           |                  | 1.25        | 88               | 84   | 81 | 78 | 87 | 83   | 80 | 78 | 85 | 82   | 80 | 78 | 84 | 81   | 79 | 77 | 76 |     |    |   |  |   |
| 下方投影面積   |           | c m <sup>2</sup> | 1.5         | 90               | 86   | 83 | 81 | 89 | 85   | 83 | 81 | 87 | 84   | 82 | 80 | 85 | 83   | 81 | 80 | 78 |     |    |   |  |   |
|          |           |                  | 等価発光面積      | c m <sup>2</sup> | 2.0  | 92 | 89 | 87 | 85   | 91 | 88 | 86 | 84   | 89 | 87 | 85 | 84   | 88 | 86 | 84 | 83  | 81 |   |  |   |
| 取付<br>高さ | 器具間隔最大限   |                  | 2.5         | 93               | 91   | 89 | 87 | 92 | 90   | 88 | 87 | 91 | 89   | 87 | 86 | 89 | 87   | 86 | 85 | 83 |     |    |   |  |   |
|          | 横方向 ( A ) |                  | 縦方向 ( B )   |                  | 3.0  | 94 | 92 | 90 | 89   | 93 | 91 | 90 | 88   | 91 | 90 | 88 | 87   | 90 | 88 | 87 | 86  | 84 |   |  |   |
| H m      | 0.47 H m  |                  | 0.47 H m    |                  | 4.0  | 95 | 94 | 92 | 91   | 94 | 93 | 92 | 90   | 93 | 91 | 90 | 89   | 91 | 90 | 89 | 88  | 86 |   |  |   |
|          |           |                  |             |                  | 5.0  | 96 | 95 | 94 | 93   | 95 | 94 | 93 | 92   | 93 | 92 | 91 | 90   | 91 | 91 | 90 | 89  | 87 |   |  |   |
|          |           |                  |             |                  | 7.0  | 97 | 96 | 95 | 94   | 96 | 95 | 94 | 93   | 94 | 93 | 93 | 92   | 92 | 91 | 91 | 90  | 88 |   |  |   |
|          |           |                  |             |                  | 10.0 | 98 | 97 | 96 | 96   | 96 | 96 | 95 | 95   | 94 | 94 | 93 | 93   | 93 | 92 | 92 | 91  | 89 |   |  |   |

