

屋内照明器具特性	
品番 (品名)	XAD3 1 2 8 V
光源	L L D 3 0 2 0 V C E 1 × 1 7 9 5 . 0 l m
管理番号	K 0 1 8 7 6 6 6 (1) D R 1
B Z 分類	B Z 1

器具効率		88 %	反射率	天井	80 %				70 %				50 %				30 %				0 %
				壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
上方光束		0 %	室指数	床	10 %				10 %				10 %				10 %				0 %
下方光束		88 %		照明率 (X 0 . 0 1) Z C M																	
保守率		良	0 . 6 7	0 . 6	75	70	66	64	74	69	66	64	73	69	66	64	72	68	66	64	63
		中	0 . 6 3	0 . 8	80	75	72	70	79	75	72	70	78	74	71	69	77	73	71	69	68
		否	0 . 5 6	1 . 0	83	79	76	74	82	78	75	73	81	77	75	73	79	77	74	73	72
				1 . 2 5	85	82	79	77	84	81	79	77	83	80	78	76	82	79	77	76	74
下方投影面積		c m ²		1 . 5	87	84	81	79	86	83	81	79	84	82	80	78	83	81	79	78	76
等価発光面積		c m ²		2 . 0	89	86	84	82	88	86	84	82	86	84	83	81	85	83	82	81	79
取付 高さ	器具間隔最大限		2 . 5	90	88	86	85	89	87	86	84	88	86	84	83	86	85	83	82	81	
	横方向 (A)	縦方向 (B)	3 . 0	91	89	88	86	90	88	87	86	88	87	86	85	87	86	84	84	82	
H m	0 . 4 3 H m	0 . 4 3 H m	4 . 0	92	91	89	88	91	90	89	88	89	88	87	86	88	87	86	85	83	
			5 . 0	93	92	90	89	92	91	90	89	90	89	88	87	88	87	87	86	84	
			7 . 0	94	93	92	91	93	92	91	90	91	90	89	89	89	88	88	87	85	
			10 . 0	94	93	93	92	93	92	92	91	91	91	90	90	89	89	89	88	86	

