

屋内照明器具特性

| | | | | | | | | | | | | | | | |
|---------|--------------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | L G W 5 6 9 3 4 B F | | | | | | | | | | | | | | |
| 光源 | LDA5 L - D - G - E17 / S / Z4 ×1 440.0 l m | | | | | | | | | | | | | | |
| 管理番号 | K0138523 (1) DR1 | | | | | | | | | | | | | | |
| BZ分類 | BZ10 / 0.9 / BZ9 / 3.5 / BZ10 / 4.5 / BZ9 | | | | | | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | |
|--------|---------|-----------------|-------------------|------|-----|-----|------|------|-----|-----|------|------|-----|-----|------|------|-----|-----|-----|-----|
| 器具効率 | 74 % | 天井 | 80 % | | | | 70 % | | | | 50 % | | | | 30 % | | | | 0 % | |
| | | | 壁 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 0 % |
| 上方光束 | 40 % | 反射率 | 10 % | | | | 10 % | | | | 10 % | | | | 10 % | | | | 0 % | |
| 下方光束 | 34 % | | 床 | 10 % | | | | 10 % | | | | 10 % | | | | 10 % | | | | 0 % |
| 室指数 | | | 照明率 (X0.01) ZCM | | | | | | | | | | | | | | | | | |
| 保守率 | 良 | 0.63 | 0.6 | 3.2 | 2.3 | 1.7 | 1.3 | 2.9 | 2.1 | 1.5 | 1.2 | 2.3 | 1.7 | 1.2 | 9 | 1.8 | 1.3 | 1.0 | 7 | 3 |
| | 中 | 0.6 | 0.8 | 3.8 | 2.9 | 2.3 | 1.8 | 3.4 | 2.6 | 2.1 | 1.6 | 2.8 | 2.1 | 1.7 | 1.3 | 2.1 | 1.7 | 1.3 | 1.0 | 5 |
| | 否 | 0.56 | 1.0 | 4.2 | 3.3 | 2.7 | 2.2 | 3.8 | 3.0 | 2.5 | 2.0 | 3.1 | 2.5 | 2.0 | 1.7 | 2.4 | 1.9 | 1.6 | 1.3 | 7 |
| | | | 1.25 | 4.6 | 3.8 | 3.2 | 2.7 | 4.2 | 3.5 | 2.9 | 2.5 | 3.4 | 2.8 | 2.4 | 2.0 | 2.6 | 2.2 | 1.9 | 1.6 | 9 |
| 下方投影面積 | | cm ² | 1.5 | 4.9 | 4.2 | 3.6 | 3.1 | 4.5 | 3.8 | 3.3 | 2.8 | 3.6 | 3.1 | 2.7 | 2.3 | 2.8 | 2.4 | 2.1 | 1.8 | 1.0 |
| 等価発光面積 | | cm ² | 2.0 | 5.4 | 4.7 | 4.1 | 3.7 | 4.9 | 4.3 | 3.8 | 3.4 | 4.0 | 3.5 | 3.1 | 2.8 | 3.1 | 2.8 | 2.5 | 2.2 | 1.3 |
| 取付高さ | 器具間隔最大限 | | 2.5 | 5.6 | 5.0 | 4.5 | 4.1 | 5.1 | 4.6 | 4.1 | 3.8 | 4.2 | 3.8 | 3.4 | 3.1 | 3.3 | 3.0 | 2.7 | 2.5 | 1.5 |
| | 横方向 (A) | 縦方向 (B) | 3.0 | 5.8 | 5.3 | 4.8 | 4.4 | 5.3 | 4.8 | 4.4 | 4.1 | 4.4 | 4.0 | 3.7 | 3.4 | 3.5 | 3.2 | 2.9 | 2.7 | 1.7 |
| Hm | 0.00Hm | 0.00Hm | 4.0 | 6.1 | 5.6 | 5.2 | 4.9 | 5.6 | 5.2 | 4.8 | 4.5 | 4.6 | 4.3 | 4.0 | 3.7 | 3.7 | 3.4 | 3.2 | 3.0 | 1.9 |
| | | | 5.0 | 6.3 | 5.9 | 5.5 | 5.2 | 5.7 | 5.4 | 5.1 | 4.8 | 4.8 | 4.5 | 4.2 | 4.0 | 3.8 | 3.6 | 3.4 | 3.2 | 2.1 |
| | | | 7.0 | 6.5 | 6.2 | 5.9 | 5.6 | 5.9 | 5.7 | 5.4 | 5.2 | 5.0 | 4.7 | 4.5 | 4.3 | 4.0 | 3.8 | 3.7 | 3.5 | 2.3 |
| | | | 10.0 | 6.6 | 6.4 | 6.2 | 6.0 | 6.1 | 5.9 | 5.7 | 5.5 | 5.1 | 4.9 | 4.8 | 4.6 | 4.2 | 4.0 | 3.9 | 3.8 | 2.5 |

