

屋内照明器具特性	
品番 (品名)	L G W8 5 2 2 1 S
光源	L L D 3 0 2 0 M L C B 1 × 1 7 1 5 . 0 l m
管理番号	K 0 1 9 0 5 7 5 (0) D R 1
B Z 分類	B Z 1 0

器具効率		6 1 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否	0 . 6 3	0 . 6	2 6	1 8	1 3	9	2 4	1 6	1 2	9	1 9	1 3	1 0	7	1 5	1 0	7	5	2
			0 . 6	0 . 8	3 1	2 3	1 8	1 4	2 8	2 1	1 6	1 3	2 3	1 7	1 3	1 0	1 8	1 4	1 0	8	4
			0 . 5 6	1 . 0	3 5	2 7	2 1	1 7	3 1	2 5	2 0	1 6	2 5	2 0	1 6	1 3	2 0	1 6	1 3	1 0	5
				1 . 2 5	3 8	3 1	2 5	2 1	3 5	2 8	2 3	1 9	2 8	2 3	1 9	1 6	2 2	1 8	1 5	1 3	7
下方投影面積		c m ²	1 . 5	4 0	3 4	2 8	2 4	3 7	3 1	2 6	2 2	3 0	2 5	2 2	1 8	2 4	2 0	1 7	1 5	9	
			等価発光面積	c m ²	2 . 0	4 4	3 8	3 3	2 9	4 0	3 5	3 1	2 7	3 3	2 9	2 5	2 2	2 6	2 3	2 0	1 8
取付 高さ	器具間隔最大限		2 . 5	4 6	4 1	3 7	3 3	4 2	3 8	3 4	3 0	3 5	3 1	2 8	2 5	2 8	2 5	2 3	2 1	1 3	
	横方向 (A) 縦方向 (B)		3 . 0	4 8	4 3	3 9	3 5	4 4	4 0	3 6	3 3	3 7	3 3	3 0	2 8	3 0	2 7	2 5	2 3	1 5	
H m	0 . 0 0 H m	1 . 7 1 H m	4 . 0	5 0	4 6	4 3	4 0	4 6	4 3	3 9	3 7	3 9	3 6	3 3	3 1	3 1	2 9	2 7	2 5	1 7	
			5 . 0	5 2	4 8	4 5	4 2	4 8	4 5	4 2	3 9	4 0	3 8	3 5	3 3	3 3	3 1	2 9	2 7	1 9	
			7 . 0	5 4	5 1	4 8	4 6	5 0	4 7	4 5	4 3	4 2	4 0	3 8	3 6	3 4	3 3	3 1	3 0	2 1	
			1 0 . 0	5 5	5 3	5 1	4 9	5 1	4 9	4 7	4 6	4 3	4 2	4 0	3 9	3 6	3 5	3 4	3 2	2 3	

