

屋内照明器具特性

品番（品名）	L G W4 5 9 1 0 K
光源	L D A 4 L - H - E 1 7 / S / 4 x 1 4 4 0 . 0 l m
管理番号	K 0 1 2 6 4 6 8 (0) D B 1
B Z 分類	B Z 1 0

器具効率		67 %	反射率	天井	80 %				70 %				50 %				30 %				0 %
				壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
				床	10 %				10 %				10 %				10 %				0 %
上方光束		50 %	室指数	照明率 (X0.01)																	ZCM
下方光束		17 %																			
保守率	良	0.63	0.6	28	20	15	12	25	18	13	10	18	13	10	7	12	9	6	5	0	
	中	0.6	0.8	33	25	20	16	29	22	18	14	21	17	13	10	14	11	9	7	1	
	否	0.56	1.0	37	29	24	20	32	26	21	18	24	19	16	13	16	13	10	8	1	
下方投影面積		c m ²	1.25	40	33	28	24	35	29	25	21	26	22	18	16	18	15	12	10	2	
			1.5	43	36	31	27	38	32	28	24	28	24	21	18	19	16	14	12	3	
等価発光面積		c m ²	2.0	46	41	36	32	41	36	32	28	31	27	24	21	21	18	16	14	4	
			2.5	49	44	39	36	43	39	35	32	32	29	26	24	22	20	18	16	5	
取付高さ	器具間隔最大限		3.0	50	46	42	38	45	41	37	34	34	31	28	26	23	21	20	18	6	
	H _m	0.00 H _m	0.00 H _m	4.0	53	49	45	42	47	43	40	38	35	33	31	29	25	23	22	7	
				5.0	54	51	48	45	48	45	43	40	37	35	33	31	26	24	23	8	
				7.0	56	53	51	49	50	47	45	43	38	36	35	33	27	26	25	10	
				10.0	57	55	53	52	51	49	48	46	39	38	37	36	28	27	26	11	

