

屋内照明器具特性	
品番 (品名)	L G W8 5 0 6 8 Y
光源	L D A 4 L - H - E 1 7 / S / 4 × 1 4 4 0 . 0 l m
管理番号	K 0 1 2 5 7 2 9 (1) D B 1
B Z 分類	B Z 1 0

器具効率		5 7 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %			
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %			
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %			
				室指数	照明率 (X 0 . 0 1) Z C M																			
保守率		良 中 否	0 . 6 3	0 . 6	0 . 6	0 . 5 6	0 . 6	2 4	1 7	1 2	9	2 2	1 5	1 1	8	1 8	1 3	9	6	1 4	1 0	7	5	2
			0 . 6	0 . 8	2 9	2 1	1 6	1 3	2 6	2 0	1 5	1 2	2 1	1 6	1 2	1 0	1 7	1 3	1 0	8	4			
			1 . 0	3 2	2 5	2 0	1 6	2 9	2 3	1 8	1 5	2 4	1 9	1 5	1 2	1 9	1 5	1 2	1 0	5				
			1 . 2 5	3 5	2 8	2 3	1 9	3 2	2 6	2 2	1 8	2 6	2 2	1 8	1 5	2 1	1 7	1 4	1 2	7				
下方投影面積		c m ²	1 . 5	3 8	3 1	2 6	2 2	3 4	2 9	2 4	2 1	2 8	2 4	2 0	1 7	2 3	1 9	1 6	1 4	9				
等価発光面積			c m ²	2 . 0	4 1	3 5	3 1	2 7	3 8	3 3	2 8	2 5	3 1	2 7	2 4	2 1	2 5	2 2	2 0	1 7	1 1			
取付高さ			器具間隔最大限		2 . 5	4 3	3 8	3 4	3 0	4 0	3 5	3 1	2 8	3 3	3 0	2 7	2 4	2 7	2 4	2 2	2 0	1 3		
		横方向 (A)		縦方向 (B)		3 . 0	4 5	4 0	3 6	3 3	4 1	3 7	3 4	3 1	3 5	3 1	2 9	2 6	2 8	2 6	2 4	2 2	1 4	
H m		0 . 0 0 H m		0 . 0 0 H m		4 . 0	4 7	4 3	4 0	3 7	4 3	4 0	3 7	3 4	3 6	3 4	3 1	2 9	3 0	2 8	2 6	2 4	1 7	
						5 . 0	4 8	4 5	4 2	3 9	4 5	4 2	3 9	3 7	3 8	3 5	3 3	3 1	3 1	2 9	2 8	2 6	1 8	
						7 . 0	5 0	4 7	4 5	4 3	4 6	4 4	4 2	4 0	3 9	3 8	3 6	3 4	3 3	3 1	3 0	2 9	2 1	
						1 0 . 0	5 1	4 9	4 7	4 6	4 8	4 6	4 4	4 3	4 1	3 9	3 8	3 7	3 4	3 3	3 2	3 1	2 2	

