

屋内照明器具特性	
品番 (品名)	L G B 1 0 8 5 9
光源	L L D 3 0 2 0 L C T 1 × 1 7 9 5 . 0 l m
管理番号	K 0 1 9 0 1 1 0 (2) D R 1
B Z 分類	B Z 1

器具効率		8 9 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
上方光束		0 %	室指数	照明率 (X 0 . 0 1) Z C M																	
下方光束		8 9 %																			
保守率		良	0 . 6 7	0 . 6	7 6	7 1	6 7	6 5	7 5	7 0	6 7	6 5	7 4	7 0	6 7	6 5	7 3	6 9	6 7	6 5	6 4
		中	0 . 6 3	0 . 8	8 1	7 6	7 3	7 1	8 0	7 6	7 3	7 1	7 9	7 5	7 3	7 1	7 8	7 5	7 2	7 1	7 0
		否	0 . 5 6	1 . 0	8 4	8 0	7 7	7 5	8 3	7 9	7 7	7 5	8 2	7 9	7 6	7 4	8 0	7 8	7 6	7 4	7 3
				1 . 2 5	8 6	8 3	8 0	7 8	8 6	8 2	8 0	7 8	8 4	8 1	7 9	7 8	8 3	8 0	7 9	7 7	7 6
下方投影面積		c m ²		1 . 5	8 8	8 5	8 3	8 1	8 7	8 4	8 2	8 0	8 6	8 3	8 1	8 0	8 4	8 2	8 1	7 9	7 8
等価発光面積			c m ²	2 . 0	9 0	8 8	8 6	8 4	8 9	8 7	8 5	8 4	8 8	8 6	8 4	8 3	8 6	8 4	8 3	8 2	8 1
取付	器具間隔最大限		2 . 5	9 1	8 9	8 8	8 6	9 0	8 9	8 7	8 6	8 9	8 7	8 6	8 5	8 7	8 6	8 5	8 4	8 2	
高さ	横方向 (A)		縦方向 (B)	3 . 0	9 2	9 0	8 9	8 8	9 1	9 0	8 8	8 7	8 9	8 8	8 7	8 6	8 8	8 7	8 6	8 5	8 3
H m	0 . 4 2 H m		0 . 4 2 H m	4 . 0	9 3	9 2	9 1	9 0	9 2	9 1	9 0	8 9	9 0	8 9	8 8	8 8	8 9	8 8	8 7	8 6	8 5
				5 . 0	9 4	9 3	9 2	9 1	9 3	9 2	9 1	9 0	9 1	9 0	8 9	8 9	8 9	8 9	8 8	8 7	8 5
				7 . 0	9 4	9 4	9 3	9 2	9 3	9 3	9 2	9 1	9 2	9 1	9 0	9 0	9 0	8 9	8 9	8 9	8 6
				1 0 . 0	9 5	9 4	9 4	9 3	9 4	9 3	9 3	9 3	9 2	9 2	9 1	9 1	9 0	9 0	9 0	8 9	8 7

