

屋内照明器具特性	
品番 (品名)	NNFS 4 2 7 0 0
光源	LDL40S . N / 14 / 26 (2600A) × 2 2600 . 0 1 m
管理番号	K0126621 (8) DB 1
BZ分類	BZ5

器具効率	93 %	天井	80 %				70 %				50 %				30 %				0 %	
		壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %	
上方光束	0 %	床	10 %				10 %				10 %				10 %				0 %	
下方光束	93 %	室指数	照明率 (X0.01)																ZCM	
保守率	良	0.81	0.6	51	40	32	27	50	39	32	27	48	38	32	27	46	37	31	27	25
	中	0.77	0.8	61	50	42	37	59	49	42	37	57	48	41	37	55	47	41	36	34
	否	0.68	1.0	67	57	50	44	66	56	49	44	63	55	48	43	60	53	48	43	41
			1.25	73	64	57	51	71	63	56	51	68	61	55	51	66	59	54	50	48
下方投影面積		cm ²	1.5	77	68	62	57	75	67	61	56	72	66	60	56	70	64	59	55	53
等価発光面積		cm ²	2.0	82	75	70	65	81	74	69	64	78	72	68	64	75	71	66	63	61
取付高さ	器具間隔最大限		2.5	86	80	75	70	84	79	74	70	81	77	73	69	79	75	71	68	66
	横方向 (A)	縦方向 (B)	3.0	88	83	78	75	87	82	78	74	84	80	76	73	81	78	75	72	70
1.5m	2.07 m	2.17 m	4.0	91	87	83	80	90	86	83	80	87	84	81	78	85	82	80	77	75
2	2.74	2.74	5.0	93	90	87	84	92	89	86	83	89	86	84	82	87	84	82	81	78
2.5	3.41	3.32	7.0	95	93	90	88	94	92	89	87	91	89	88	86	89	87	86	84	82
3	4.07	3.92	10.0	97	95	93	92	96	94	92	91	93	92	90	89	91	90	89	88	85

