

屋内照明器具特性

品番 (品名)	NNFS 4 1 0 3 8 J				
光源	LDL40S . N29 / 31 - 9 ×1 3150.0 lm				
管理番号	K0126131 (4) DB 1				
BZ分類	BZ6				

器具効率	98%	天井	80%				70%				50%				30%				0%		
	上方光束		15%	壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0%
	下方光束		83%		床	10%				10%				10%				10%			
室指数	照明率 (X0.01)																			ZCM	
保守率	良	0.83	0.6	51	38	30	25	49	37	30	24	45	35	28	23	41	33	27	22	19	
	中	0.81	0.8	60	48	40	34	57	46	39	33	53	43	37	32	49	41	35	30	27	
	否	0.77	1.0	66	55	46	40	63	53	45	39	58	49	43	38	54	46	41	36	32	
	下方投影面積	c m ²		1.25	72	61	53	47	69	59	52	46	63	55	49	44	58	52	46	42	38
等価発光面積	c m ²		1.5	76	66	58	52	73	64	57	51	67	60	54	49	62	56	51	47	42	
	c m ²		2.0	81	73	66	60	78	70	64	59	72	66	61	56	67	62	57	53	48	
取付高さ	器具間隔最大限		2.5	85	77	71	66	82	75	69	64	76	70	65	61	70	66	62	58	53	
	横方向 (A)	縦方向 (B)	3.0	87	81	75	70	84	78	73	69	78	73	69	65	73	69	65	62	56	
1.5m	2.17m	2.11m	4.0	91	85	81	76	88	83	78	74	82	78	74	71	76	73	70	67	61	
2	2.87	2.66	5.0	93	88	84	80	90	86	82	78	84	80	77	74	78	76	73	71	64	
2.5	3.56	3.23	7.0	95	92	89	85	92	89	86	83	87	84	81	79	81	79	77	75	68	
3	4.25	3.81	10.0	97	95	92	90	94	92	90	87	89	87	85	83	83	82	80	79	72	

