

屋内照明器具特性	
品番 (品名)	XS Z B 1 0 1 1 5
光源	L L D 2 4 1 1 V C B 1 × 1 5 0 0 . 0 l m
管理番号	K 0 1 9 3 6 8 1 (0) D B 1
B Z 分類	B Z 1 / 4 . 5 / B Z 2

器具効率		9 9 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %	
上方光束		7 %	室指数	照明率 (X 0 . 0 1) Z C M																		
下方光束				9 2 %																		
保守率		良 中 否	0 . 6	7 4	6 7	6 2	5 9	7 3	6 6	6 2	5 9	7 1	6 5	6 1	5 8	6 9	6 4	6 0	5 8	5 6		
			0 . 8	8 1	7 5	7 0	6 6	8 0	7 4	6 9	6 6	7 7	7 2	6 8	6 5	7 5	7 1	6 7	6 5	6 3		
			1 . 0	8 6	7 9	7 5	7 2	8 4	7 8	7 4	7 1	8 1	7 7	7 3	7 0	7 9	7 5	7 2	6 9	6 7		
			0 . 5 6	1 . 2 5	8 9	8 4	8 0	7 6	8 8	8 3	7 9	7 6	8 5	8 0	7 7	7 4	8 2	7 8	7 6	7 3	7 1	
下方投影面積		c m ²	1 . 5	9 2	8 7	8 3	8 0	9 0	8 5	8 2	7 9	8 7	8 3	8 0	7 8	8 4	8 1	7 8	7 6	7 3		
			等価発光面積	c m ²	2 . 0	9 5	9 1	8 7	8 4	9 3	8 9	8 6	8 4	9 0	8 7	8 4	8 2	8 7	8 4	8 2	8 0	7 7
取付 高さ	器具間隔最大限		2 . 5	9 7	9 3	9 0	8 8	9 5	9 2	8 9	8 7	9 2	8 9	8 7	8 5	8 8	8 6	8 4	8 3	7 9		
	横方向 (A)		縦方向 (B)		3 . 0	9 8	9 5	9 2	9 0	9 6	9 3	9 1	8 9	9 3	9 1	8 8	8 7	9 0	8 8	8 6	8 5	8 1
H m	0 . 7 4 H m		0 . 7 4 H m		4 . 0	1 0 0	9 7	9 5	9 3	9 8	9 6	9 4	9 2	9 4	9 3	9 1	8 9	9 1	9 0	8 8	8 7	8 3
					5 . 0	1 0 1	9 9	9 7	9 5	9 9	9 7	9 5	9 4	9 5	9 4	9 2	9 1	9 2	9 1	9 0	8 9	8 5
					7 . 0	1 0 2	1 0 0	9 9	9 7	1 0 0	9 9	9 7	9 6	9 6	9 5	9 4	9 3	9 3	9 2	9 1	9 0	8 6
					1 0 . 0	1 0 3	1 0 2	1 0 1	9 9	1 0 1	1 0 0	9 9	9 8	9 7	9 6	9 6	9 5	9 4	9 3	9 3	9 2	8 7

