

屋内照明器具特性	
品番 (品名)	L R D C 3 1 4 6 V
光源	L E D 3 5 0 0 _ 7 0 _ 7 4 5 × 1 7 4 5 . 0 l m
管理番号	K 0 1 5 7 0 3 4 (0) D 1
B Z 分類	B Z 3

器具効率		1 0 0 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %	
上方光束		0 %	室指数	照明率 (X 0 . 0 1)																		Z C M
下方光束				1 0 0 %																		
保守率		良 中 否	0 . 6 7	0 . 6	6 2	5 1	4 4	3 9	6 1	5 0	4 4	3 9	5 9	4 9	4 3	3 9	5 7	4 8	4 3	3 9	3 7	
			0 . 6 3	0 . 8	7 2	6 2	5 6	5 1	7 1	6 2	5 5	5 0	6 9	6 0	5 5	5 0	6 6	5 9	5 4	5 0	4 8	
			0 . 5 6	1 . 0	7 9	7 0	6 4	5 9	7 8	6 9	6 3	5 8	7 5	6 8	6 2	5 8	7 3	6 6	6 2	5 8	5 6	
				1 . 2 5	8 5	7 7	7 1	6 6	8 3	7 6	7 0	6 6	8 1	7 4	6 9	6 5	7 8	7 3	6 9	6 5	6 3	
下方投影面積		c m ²	1 . 5	8 9	8 1	7 6	7 1	8 7	8 1	7 5	7 1	8 4	7 9	7 4	7 1	8 2	7 7	7 3	7 0	6 8		
等価発光面積			c m ²	2 . 0	9 4	8 8	8 3	7 9	9 2	8 7	8 2	7 9	8 9	8 5	8 1	7 8	8 7	8 3	8 0	7 7	7 5	
取付 高さ	器具間隔最大限		2 . 5	9 6	9 2	8 7	8 4	9 5	9 1	8 7	8 3	9 2	8 9	8 5	8 2	9 0	8 7	8 4	8 1	7 9		
	横方向 (A)		縦方向 (B)	3 . 0	9 8	9 4	9 1	8 7	9 7	9 3	9 0	8 7	9 5	9 1	8 8	8 6	9 2	8 9	8 7	8 5	8 2	
H m	1 . 1 8 H m	1 . 2 2 H m	4 . 0	1 0 1	9 8	9 5	9 2	1 0 0	9 7	9 4	9 1	9 7	9 5	9 2	9 0	9 5	9 3	9 1	8 9	8 6		
			5 . 0	1 0 2	1 0 0	9 7	9 5	1 0 1	9 9	9 6	9 4	9 9	9 7	9 5	9 3	9 6	9 5	9 3	9 1	8 9		
			7 . 0	1 0 4	1 0 2	1 0 0	9 9	1 0 3	1 0 1	9 9	9 8	1 0 0	9 9	9 7	9 6	9 8	9 7	9 6	9 4	9 2		
			1 0 . 0	1 0 5	1 0 4	1 0 3	1 0 1	1 0 4	1 0 3	1 0 2	1 0 0	1 0 2	1 0 1	1 0 0	9 9	9 9	9 9	9 8	9 7	9 4		

